


EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
284	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
318	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
319	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
321	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
322	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046

Michelle McGowan

Analyst


 Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

EMSL Analytical, Inc. 208 Stonehenge Lane, Carle Place, NY 11514
 Phone: (516) 997-7251 Fax: (516) 997-7528

CITY_21MC100_003008168