NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
323	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
324	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
325	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
6	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
327	1310.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046
328	1330.00	None Detected			0	0.0635	0.0046	<15.75	<0.0046

12

Daniel Clarke
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision, is available upon request.

Accredited for NVLAP (Lab Code 101048-0), NY ELAP 11459, CA ELAP 2039, CT PH-0163

CITY_21MC100_003008169

NYC-WTC_000205571