

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410


Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu - < 5\mu$	Non-Asbestos $\geq 5\mu$			(S/mm ²)	(S/cc)
329	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
330	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
331	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
	1330.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
333	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
334	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043

Michelle McGowan

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

EMSL Analytical, Inc. is a member of the NVLAP PLM/TEM #101045-10, NY CLAP #1459, CA CLAP #2359, CT PLM-0249

CITY_21MC100_003008170

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non- Asbestos			(S/mm ³)	(S/cc)
335	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
336	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
337	1400.00	Chrysotile	3	0	0	0.0635	0.0043	47.24	0.0130
	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
339	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042
340	1450.00	None Detected			0	0.0635	0.0042	<15.75	<0.0042

Michelle McGowan

Analyst


 Approved
Signatory


Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PRACTICE #101009-10 NY ELAP 11469 CAL LAP 0333, CE PM 0700

CITY_21MC100_003008171

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001


Ref Number: LI0116410

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5µ - < 5µ	Non- Asbestos ≥ 5µ			(S/mm ²)	(S/cc)
341	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
342	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
343	1540.00	None Detected		0	0.0635	0.0039	<15.75	<0.0039
14	1540.00	None Detected		0	0.0508	0.0049	<19.65	<0.0049
345	1540.00	None Detected		0	0.0508	0.0049	<19.65	<0.0049
346	1550.00	None Detected		0	0.0508	0.0049	<19.65	<0.0049

Michelle McGowan

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

EMSL Analytical, Inc. is a member of the NYLAP (NY) and CALAP (CA) programs. NYLAP is a member of the NYLAP (NY) and CALAP (CA) programs. NYLAP is a member of the NYLAP (NY) and CALAP (CA) programs.

CITY_21MC100_003008172