


EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Wednesday, October 31, 2001

Ref Number: LI0116450

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: BLDG 3 40 HARRISON ST NY, NY 32ND FLR

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non-Asbestos			(S/mm ²)	(S/cc)
242	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
243	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
244	1300.00	None Detected		1	0.0635	0.0047	<15.75	<0.0047
	1290.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
246	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
371	1200.00	None Detected		0	0.0635	0.0051	<15.75	<0.0051

Keith McWilliams

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PL-MTELM-010105-10, NY ELAP 11460, CA ELAP 2539, IL ELAP 0210

CITY_21MC100_003008177