

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK, NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	Non- Asbestos $\geq 5\mu$			(S/mm ²)	(S/cc)
207	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
208	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
209	1400.00	None Detected		0	0.0635	0.0043	<15.75	<0.0043
210	1390.00	None Detected		0	0.0635	0.0044	<15.75	<0.0044
211	1370.00	None Detected		0	0.0635	0.0044	<15.75	<0.0044
212	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045

Daniel Clarke

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM# EM #101048-10, NY ELAP 11460, CA ELAP 2839, CT PR-0249

CITY_21MC100_003008227

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK, NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
213	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
214	1360.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
215	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
216	1350.00	None Detected		0	0.0635	0.0045	<15.75	<0.0045
217	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
218	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038

Daniel Clarke

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including daily confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Request for NVLAP PUM/TEM #101048-10 NY ELAP 11473 CALAP 2033, CE PH-0219

2

CITY_21MC100_003008228

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
219	1600.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
220	1590.00	None Detected		0	0.0635	0.0038	<15.75	<0.0038
221	1590.00	None Detected		0	0.0508	0.0048	<19.69	<0.0048
222	1530.00	None Detected		0	0.0508	0.0050	<19.69	<0.0050
223	1580.00	Chrysotile Anthophyllite	0 1	1 0	0.0508	0.0048	39.37	0.0096
224	1580.00	None Detected		0	0.0508	0.0048	<19.69	<0.0048

Daniel Clarke

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVTAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3

Accredited for NVTAP by NVTAP #101048-10, NY ELAP 11459, CALAP 2017, CT PEL0049

CITY_21MC100_003008229