

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001


Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
225	1580.00	None Detected		0	0.0508	0.0048	<19.69	<0.0048
226	1600.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
227	1600.00	None Detected		2	0.0508	0.0047	<19.69	<0.0047
228	1600.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
229	1600.00	None Detected		0	0.0508	0.0047	<19.69	<0.0047
230	1600.00	None Detected		1	0.0508	0.0047	<19.69	<0.0047


Michelle McGowan

Analyst


 Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

4



Permitted for NVLAP PLM/TEM #101045-10, NY ELAP 11469, CA ELAP 2539, C1 FH-0049

CITY_21MC100_003008230

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK, NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
231	0.00	Not Submitted		0	0.0000			
232	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
233	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
234	1450.00	None Detected		3	0.0635	0.0042	<15.75	<0.0042
235	1450.00	None Detected		0	0.0635	0.0042	<15.75	<0.0042
236	1450.00	None Detected		2	0.0635	0.0042	<15.75	<0.0042

Michelle McGowan

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT PH 0249

CITY_21MC100_003008231

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non- Asbestos			(S/mm ²)	(S/cc)
237	1500.00	Chrysotile	0	1	1	0.0635	0.0040	15.75	0.0040
238	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
239	1500.00	None Detected			1	0.0635	0.0040	<15.75	<0.0040
240	1500.00	None Detected			0	0.0635	0.0040	<15.75	<0.0040
241	1490.00	None Detected			0	0.0635	0.0041	<15.75	<0.0041
242	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047

Michelle McGowan

Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT P110449

CITY_21MC100_003008232

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001


Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK, NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES			Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ - < 5μ	≥ 5μ	Non- Asbestos			(S/mm ²)	(S/cc)
247	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
248	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
249	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
250	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
251	1300.00	Not Submitted			0	0.0000			
252	1200.00	Chrysotile	1	0	1	0.0635	0.0051	15.75	0.0051

Michelle McGowan

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts accuracy and precision) is available upon request.

7

Approved for NVLAP PLM/TEM #101046-10, NY ELAP 11459, CA ELAP 2339, CT PL 0205

CITY_21MC100_003008233