

EMSL Analytical, Inc.

208 Stonehenge Lane

Carle Place, NY 11514

Phone: (516) 997-7251

Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise

270 Swinton Avenue

Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK , NEW YORK 10013

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	$\geq 5\mu$ Non- Asbestos			(S/mm ²)	(S/cc)
253	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
254	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
255	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
256	1200.00	None Detected		0	0.0762	0.0042	<13.12	<0.0042
257	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
258	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046

Daniel Clarke

Analyst


Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Revised for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2739, CT PH-0249

CITY_21MC100_004034449

EMSL Analytical, Inc.208 Stonehenge Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Friday, October 26, 2001

Ref Number: LI0116316

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)****Project: PROJECT: BUILDING # 3 - 40 HARRISON STREET, NEW YORK, NEW YORK 10013**

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			$\geq 0.5\mu$ - < 5μ	Non- Asbestos			(S/mm ²)	(S/cc)
259	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
260	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
261	0.00	Not Submitted		0	0.0000			
262	0.00	None Detected		0	0.0762		<13.12	
263	0.00	None Detected		0	0.0635		<15.75	
264	0.00	None Detected		0	0.0635		<15.75	

Daniel Clarke

Analyst


 Approved
 Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

9


 Approved for NVLAP PLM/TEM #101048-10, NY ELAP 11499, CA ELAP 2433, CT PL 0040

CITY_21MC100_004034450