EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

EMSL

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	≥ 5µ	Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	(S/cc)
347	1540.00	None Detected			0	0.0508	0.0049	<19.69	<0.0049
348	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
349	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
350	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
351	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049
352	1250.00	None Detected			0	0.0635	0.0049	<15.75	<0.0049

Daniel Clarke
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM-TEM #101048-10, NY ELAP 11459, CA ELAP 2339, CT PH-0244

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
353	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
354	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
355	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
356	1660.00	None Detected			0	0.0635	0.0037	<15.75	<0.0037
357	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
358	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047

Daniel Clarke
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2350, CT PH-0249

CITY_21MC100_003008250

NYC-WTC_000205621

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
359	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
360	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
361	1300.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
362	1290.00	None Detected			0	0.0635	0.0047	<15.75	<0.0047
363	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
364	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043

Daniel Clarke
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-0, NY ELAP 11459, CA ELAP 2339, CT PH 0240

8

NYC-WTC_000205622

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Tuesday, October 30, 2001

Ref Number: LI0116410

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: BLDG #3 - 40 HARRISON ST NY, NY 25TH FLR - 01231

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES ≥ 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
365	1400.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
366	1410.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
367	1420.00	None Detected			0	0.0635	0.0043	<15.75	<0.0043
368	0.00	None Detected			0	0.0635		<15.75	
369	0.00	None Detected			0	0.0635		<15.75	
370	0.00	None Detected			0	0.0635		<15.75	

Daniel Clarke
Analyst

Approved
Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #101048-10, NY ELAP 11469, CA ELAP 2339, CT PH-0249

CITY_21MC100_003008252

NYC-WTC_000205623