

Ambient Group Inc. 10 Morris Avenue, Glen Cove, NY 11542 Tele. (516) 609-0009 Fax (516) 609-8271 ELAP #10865

REPORT OF AIR SAMPLE ANALYSIS BY PHASE CONTRAST MICROSCOPY / NIOSH 7400

Page 1

Project #: 0211414
 Client: Paramount Group, Inc.
 Location: 180 Maiden Lane
 MER
 Technician: PS

Date Rcvd: 9/23/01
 Time Rcvd: 11:19 PM
 Date Analyzed: 9/23/01
 Batch #: 14830

Analyst: KH
 Signed for Ambient Labs Inc. by:

Laboratory ID Field ID	Date/Time Collected	Sample Type	Location	Detection Limit (fibers/cc)	Concentration (fibers/cc)	Remarks
A2K338209 3231-01	9/23/01 7:20 PM	REOCC	5TH FLOOR INSIDE NORTH PLENUM	0.001	LT DETECT	
A2K338210 3231-02	9/23/01 7:21 PM	REOCC	IN FAN ACS-1	0.001	LT DETECT	
A2K338211 3231-03	9/23/01 7:22 PM	REOCC	IN FAN ACS-4	0.001	LT DETECT	
A2K338212 3231-04	9/23/01 7:25 PM	REOCC	INSIDE SOUTH PLENUM	0.001	LT DETECT	
A2K338213 3231-05	9/23/01	BLNK	FIELD BLANK	0.000	N/A	
A2K338214 3232-01	9/23/01 3:10 PM	IAQ	AT ENTRANCE TO NORTH PLENUM	0.002	LT DETECT	
A2K338215 3232-02	9/23/01 3:11 PM	IAQ	ADJACENT ACS-1	0.002	LT DETECT	
A2K338216 3232-03	9/23/01 3:12 PM	IAQ	ADJACENT ACS-4	0.002	LT DETECT	

Sample Type Key: CONTAM = Contamination, BLNK = Field Blank, REOCC = Reoccupany/Final Clearance, BKGRND = Background, PERS = Personal
 Results Key: N/A = not applicable, LT DETECT = less than detection limit
 Detection Limit = (7 fibers/mm2 filter area)(0.00785 mm2/field)(100 field/sample) = 5.5 fibers/sample volume

P. 05

FAX NO. 212 768 1540

AMBIENT GROUP INC

SEP-23-01 SUN 11:46 PM

CITY_21MC100_003008520