

EMSL Analytical, Inc.208 Stonchings Lane
Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528

EMSLAttn: J.C. Broderick
J.C. BRODERICK & ASSOCIATES
101-4 Collin Drive
Holbrook, NY 11741

Wednesday, February 06, 2002

Ref Number: LI022019

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)**

Project: 37 MURRAY STREET APT-5A PRJ NO. 02-2564

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5µ - < 5µ	Non-Asbestos ≥ 5µ			(S/mm ³)	(S/cc)
1	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
2	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
3	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042
4	1800.00	None Detected		0	0.0508	0.0042	<19.69	<0.0042

Daniel Clarke
AnalystApproved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

EMSL Analytical, Inc. 208 Stonchings Lane, Carle Place, NY 11514, CA 94025, CT 06424