

SciLab Job #: 201102187

Client Name: Warren & Panzer Engineering, P.C.

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

299.07.130; New York Law School ; 57 Worth Street & 240 Church Street Entire Buildings (Final Clearance)

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
15	32 240 Church Street - 3rd Floor		1540	.06	0.0042	0.0	0.0	0.0	<16.7	<16.7	<0.0042	<0.0042	NSD
16	33 240 Church Street - 2nd Floor		1550	.06	0.0041	0.0	0.0	0.0	<16.7	<16.7	<0.0041	<0.0041	NSD
17	34 240 Church Street - 1st Floor		1520	.06	0.0042	0.0	0.0	0.0	<16.7	<16.7	<0.0042	<0.0042	NSD
18	35 240 Church Street - Basement		1500	.06	0.0043	0.0	0.0	0.0	<16.7	<16.7	<0.0043	<0.0043	NSD
19**	36 Blank												
20**	37 Blank												

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____; Analyzed By: HEA Date: 10/14/01

Clean Massey

NVLAP#: 200546-0

CITY_21MC100_011087611

