

SciLab Job #: 201102031

Client Name: Warren & Panzer Engineering, P.C.

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

299.07.130; New York Law School; 47 Worth Street, Basement - 5th Floor / FINAL CLEARANCE

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	5th Floor	01	1600	.1	0.0024	0.0	0.0	0.0	<10	<10	<0.0024	<0.0024	NSD
02	4th Floor	02	1530	.1	0.0025	0.0	0.0	0.0	<10	<10	<0.0025	<0.0025	NSD
03	3rd Floor	03	1530	.1	0.0025	0.0	0.0	0.0	<10	<10	<0.0025	<0.0025	NSD
04	2nd Floor	04	1550	.1	0.0025	0.0	0.0	0.0	<10	<10	<0.0025	<0.0025	NSD
05	1st Floor	05	1550	.1	0.0025	0.0	0.0	0.0	<10	<10	<0.0025	<0.0025	NSD
06	Basement	06	1600	.1	0.0024	0.0	0.0	0.0	<10	<10	<0.0024	<0.0024	NSD
07**	Blank	07											
08**	Blank	08											

* concentration represented by the detection of 1 structure


** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:



Analyzed By:



Date: 10/12/01

Paul Mucha

NVLAP#: 200546-0

01-12-2001 10:35

SCIENTIFIC LABS

212 679 9392 P.02/03

CITY_21MC100_011087623