

ENVIRONMENTAL SERVICES INC

Tel. (718) 784-7490
Fax (718) 784-4085

CLIENT : Warren S Rancer Eng PC.	DATE : 11/4/02
PROJECT : NYC DEP / St Annas St	ANALYST : CND
BATCH # : 702.011-018	CLIENT ID # : 02
SAMPLE ID # : 702-011-019-3171	VOLUME (lt) : 1620
G.O. AREA (mm ²) : 0.013433	GO's TO ANALYZE : 4
MAGNIFICATION : 196	ACC. VOLTAGE (KeV) : 100
INSTRUMENT : JEOL 100CX II	FILTER AREA (mm ²) : 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ³):	0.0044	Eucentricity check:	
Concentration (str/cm ³):	< 0.0044	*Grid acceptance criteria check:	(A) ☒ (B) ☒
Concentration (str/mm ²):	< 18.61	**CHR. # STRUCT.:	F M C B
Number of Asbestos Structures:	0.5 ≤ < 5 μm 0 ≥ 5 μm 0	**AMPH. # STRUCT.:	F M C B
Number of Non-asbestos Structures:	0	Specify AMPH. Type:	AM ACT TR
		CRO ANTH.	

** CHR = chrysotile, AMPH = amphibole, AM = amosite, ACT = actinolite, TRE = tremolite, CRO = crocidolite, ANTH = anthophyllite