

Tel. (718) 764-7490  
Fax (718) 764-4088

TEM DEPARTMENT

| TEM AHERA COUNTSHEET 1                                                                                                      |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>NYCDEP/29 Broadway Str</i>                                                                                      | ANALYST: <i>E.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>1</i>                      |
| SAMPLE ID #: <i>T02-07-043-1164</i>                                                                                         | VOLUME (H): <i>1305</i>                    |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART B |                                            |

[illegible]

|                                                |                                             |                                  |                   |
|------------------------------------------------|---------------------------------------------|----------------------------------|-------------------|
| Analytical Sensitivity (str/cm <sup>3</sup> ): | 0.0049                                      | Eucentricity check:              |                   |
| Concentration (str/cm <sup>3</sup> ):          | < 0.0049                                    | *Grid acceptance criteria check: | (A)..... (B)..... |
| Concentration (str/mm <sup>2</sup> ):          | < 16.53                                     | **CHR. # STRUCT.:                | F M C B           |
| Number of Asbestos Structures:                 | 0.5 ≤ S < 5 μm .....<br>S ≥ 5 μm .....<br>0 | **AMPH. # STRUCT.:               | F M C B           |
| Number of Non-asbestos Structures:             | .....                                       | Specify AMPH. Type:              | AM. ACT. TRE.     |
|                                                |                                             | CRO. ANTH.                       |                   |

\*Replion covers >50%, at least 20 OO's with no overlapping or folded replica, intact OO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

\*\* CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite

NYC-WTC\_000205884

Tel. (718) 784-7400  
Fax (718) 784-4085

TEM DEPARTMENT

| TEM AHERA COUNTSHEET                                                                                                        |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>MYCDEP/29 Broadway Str</i>                                                                                      | ANALYST: <i>C.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>2</i>                      |
| SAMPLE ID #: <i>T02-07-043-1165</i>                                                                                         | VOLUME (li): <i>1308</i>                   |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART E |                                            |

[illegible]

|                                                |                            |                                  |                                                                                 |
|------------------------------------------------|----------------------------|----------------------------------|---------------------------------------------------------------------------------|
| Analytical Sensitivity (str/cm <sup>2</sup> ): | 0.0049                     | Eucentricity check:              |                                                                                 |
| Concentration (str/cm <sup>2</sup> ):          | < 0.0049                   | *Grid acceptance criteria check: | (A) <input checked="" type="checkbox"/> (B) <input checked="" type="checkbox"/> |
| Concentration (str/mm <sup>2</sup> ):          | < 16.53                    | **CHR. # STRUCT.:                | F M C B                                                                         |
| Number of Asbestos Structures:                 | 0.55S < 5µm 0<br>S ≥ 5µm 0 | **AMPH. # STRUCT.:               | F M C B                                                                         |
| Number of Non-asbestos Structures:             | 0                          | Specify AMPH. Type:              | AM. ACT. TRE.                                                                   |
|                                                |                            | CRO. ANTH.                       |                                                                                 |

\* Replicia covers >50% at least 20 GO's with no overlapping or folded replicia, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

NYC-WTC\_000205885





46-08 Greenpoint Avenue  
Long Island City, N.Y. 11104

Tel. (716) 784-7400  
Fax (716) 784-4005

TEM DEPARTMENT

**TEM AHERA COUNTSHEET**

| TEM AHERA COUNTSHEET                                                                                                       |                                            |
|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                         | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>NYCDEP/29 Broadway Str</i>                                                                                     | ANALYST: <i>E.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                 | CLIENT ID #: <i>4</i>                      |
| SAMPLE ID #: <i>T02-07-043-1167</i>                                                                                        | VOLUME (l): <i>1308</i>                    |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                              | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                  | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                           | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART E |                                            |

[illegible]

|                                                |                       |                                  |                   |
|------------------------------------------------|-----------------------|----------------------------------|-------------------|
| Analytical Sensitivity (str/cm <sup>3</sup> ): | 0.0049                | Eucentricity check:              |                   |
| Concentration (str/cm <sup>3</sup> ):          | < 0.0049              | *Grid acceptance criteria check: | (A)..... (B)..... |
| Concentration (str/mm <sup>2</sup> ):          | < 16.53               | **CHR. # STRUCT.:                | F M C B           |
| Number of Asbestos Structures:                 | 0.5 ≤ S < 5 μm 0..... | **AMPH. # STRUCT.:               | F M C B           |
|                                                | S ≥ 5 μm 0.....       | Specify AMPH. Type:              | AM. ACT. TRE      |
| Number of Non-asbestos Structures:             | 0.....                | CRO. ANTH.                       |                   |

\* Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

holos or opaque areas, <10% particulate coverage.  
 \*\* CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite

CITY\_21MC100\_002991331

NYC-WTC\_000205887



46-08 Greenpoint Avenue  
Long Island City, N.Y. 11104

Tel. (718) 784-7400  
Fax (718) 784-4088

TEM DEPARTMENT

**TEM AHERA COUNTSHEET**

| TEM AHERA COUNTSHEET                                                                                                        |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>MYCDEP/29 Broadway Str</i>                                                                                      | ANALYST: <i>G.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>5</i>                      |
| SAMPLE ID #: <i>T02-07-043-1168</i>                                                                                         | VOLUME (II): <i>1308</i>                   |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART E |                                            |

[illegible]

|                                                |          |                                  |                   |
|------------------------------------------------|----------|----------------------------------|-------------------|
| Analytical Sensitivity (str/cm <sup>3</sup> ): | 0.0049   | Eucentricity check:              |                   |
| Concentration (str/cm <sup>3</sup> ):          | < 0.0049 | *Grid acceptance criteria check: | (A)..... (B)..... |
| Concentration (str/mm <sup>3</sup> ):          | < 10.53  | **CHR. # STRUCT.: F              | M C B             |
| Number of Asbestos Structures: 0.5 ≤ S < 5 μm  | 0        | **AMPH. # STRUCT.: F             | M C B             |
| S ≥ 5 μm                                       | 0        | Specify AMPH. Type: AM.          | ACT. TRE.         |
| Number of Non-asbestos Structures:             | 0        | CRO.                             | ANTH.             |

\*Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filler, <5% holes or opaque areas, <10% particulate coverage.

\*\* CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite

CITY\_21MC100\_002991332



48-08 Greenpoint Avenue  
Long Island City, N.Y. 11104

Tel. (718) 784-7490  
Fax (718) 784-4088

TEM DEPARTMENT

**TEM AHERA COUNTSHEET**

| TEM AHERA COUNTSHEET                                                                                                        |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>NYCDEP/29 Broadway str</i>                                                                                      | ANALYST: <i>E.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>6</i>                      |
| SAMPLE ID #: <i>T02-07-043-1169</i>                                                                                         | VOLUME (l): <i>1308</i>                    |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART B |                                            |

[illegible]

|                                                |                    |                                  |                   |
|------------------------------------------------|--------------------|----------------------------------|-------------------|
| Analytical Sensitivity (str/cm <sup>2</sup> ): | 0.0049             | Eucentricity check:              |                   |
| Concentration (str/cm <sup>2</sup> ):          | 0.0049             | *Grid acceptance criteria check: | (A)..... (B)..... |
| Concentration (str/mm <sup>2</sup> ):          | 16.53              | **CHR. # STRUCT.:                | F 0, M 0 C 0 B 0  |
| Number of Asbestos Structures:                 | 0.5 ≤ S < 5 μm 0.1 | **AMPH. # STRUCT.:               | F M C B           |
|                                                | S ≥ 5 μm 0         | Specify AMPH. Type:              | AM. ACT. TRE.     |
| Number of Non-asbestos Structures:             | 0                  | CRO. ANTH.                       |                   |

\*Replica covers >50%, at least 20 OO's with no overlapping or folded replica, intact OO's have >50% coverage, <50% Undissolved filler, <5% holes or opaque areas, <10% particulate coverage.

holes or opaque areas, <10% particulate coverage.

CITY\_21MC100\_002991333

Tel. (718) 784-7400  
Fax (718) 784-4088

TEM DEPARTMENT

| TEM AHERA COUNTSHEET                                                                                                        |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>MYCDEP/29 Broadway Str</i>                                                                                      | ANALYST: <i>E.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>7</i>                      |
| SAMPLE ID #: <i>T02-07-043-11 fo</i>                                                                                        | VOLUME (l): <i>1308</i>                    |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART E |                                            |

[illegible]

|                                                |                        |                                  |               |
|------------------------------------------------|------------------------|----------------------------------|---------------|
| Analytical Sensitivity (str/cm <sup>3</sup> ): | 0.0049                 | Eucentricity check:              |               |
| Concentration (str/cm <sup>3</sup> ):          | < 0.0049               | *Grid acceptance criteria check: | (A) ✓ (B) ✓   |
| Concentration (str/mm <sup>2</sup> ):          | < 16.53                | **CHR. # STRUCT.:                | F M C B       |
| Number of Asbestos Structures:                 | 0.5 ≤ S < 5 μm ..... 0 | **AMPH. # STRUCT.:               | F M C B       |
|                                                | S ≥ 5 μm ..... 0       | Specify AMPH. Type:              | AM. ACT. TRE. |
| Number of Non-asbestos Structures:             | ..... 0                | CRO. ANTH.                       |               |

\*Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filler, <5% holo or opaque areas, <10% particulate coverage.

\*\* CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite

Tel. (718) 784-7400  
Fax (718) 784-4085

TEM DEPARTMENT

| TEM AHERA COUNTSHEET                                                                                                        |                                            |
|-----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| CLIENT: <i>Warren &amp; Panzer</i>                                                                                          | DATE: <i>7/31/02</i>                       |
| PROJECT: <i>NYCDEP/29 Broadway Str</i>                                                                                      | ANALYST: <i>E.S.</i>                       |
| BATCH #: <i>T02-07-043</i>                                                                                                  | CLIENT ID #: <i>8</i>                      |
| SAMPLE ID #: <i>T02-07-043-11 F1</i>                                                                                        | VOLUME (II): <i>1308</i>                   |
| G.O. AREA (mm <sup>2</sup> ): <i>0.008643</i>                                                                               | GO's TO ANALYZE: <i>7</i>                  |
| MAGNIFICATION: <i>194</i>                                                                                                   | ACC. VOLTAGE (KeV): <i>100</i>             |
| INSTRUMENT: <i>JEOL 100CX II</i>                                                                                            | FILTER AREA (mm <sup>2</sup> ): <i>385</i> |
| ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40<br>CFR, PART 763, APPENDIX A TO SUBPART E |                                            |

[illegible]

|                                                |                |                                  |                   |
|------------------------------------------------|----------------|----------------------------------|-------------------|
| Analytical Sensitivity (str/cm <sup>2</sup> ): | 0.0049         | Eucentricity check:              |                   |
| Concentration (str/cm <sup>2</sup> ):          | <0.0049        | *Grid acceptance criteria check: | (A)..... (B)..... |
| Concentration (str/mm <sup>2</sup> ):          | <16.53         | **CHR. # STRUCT.:                | F M C B           |
| Number of Asbestos Structures:                 | 0.55S<5µm 9... | **AMPH. # STRUCT.:               | F M C B           |
|                                                | S≥5µm 9...     | Specify AMPH. Type:              | AM. ACT. TRE.     |
| Number of Non-asbestos Structures:             | 9              | CRO. ANTH.                       |                   |

\*Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

\*\* CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite

CITY\_21MC100\_002991335