

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 124 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: NYC DEP

W&P FILE #:

PROJECT: 50 Broadway, Manhattan NY

LABORATORY:

LOCATION: FACADEANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II

CONTACT:

T02-08-018TECHNICIAN: CHETRAM RAMRAJ

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP		TIME ON OFF		TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)	Fib /m ²
01	on east end of roof left side (35 th fl)	3		3		10:05	1705	420	1260	<0.0049	<16.10
02	on east end of roof right side (35 th fl)	3		3		10:06	1706	420	1260	<0.0049	<16.10
03	At center of the roof (35 th fl)	3		3		10:07	1707	420	1260	<0.0049	<16.10
04	on west end of roof left side (35 th fl)	3		3	3	10:08	1300	172	516	<0.0046	23.9
05	on west end of roof right side (35 th fl)	3		3		10:09	1709	420	1260	<0.0049	<16.10
06	near entrance to roof	3		4		13:00	1710	250	1080	<0.0044	<11.50
07	{FIELD}										
08	{BLANK}										

SAMPLE BY: Chetram RAMRAJ DATE: 08/03/02
 SIGNATURE: Chetram Ramraj
 RELEASED BY: Chetram Ramraj DATE: 08/08/02
 SIGNATURE: Chetram Ramraj
 RECEIVED BY: E. S. S. S. S. DATE: 8/4/02
 SIGNATURE: E. S. S. S. S.

COMMENTS: *As per DEP inspector Greg Fruchman who requested me to place one sample at entrance to roof as per specs, so he asked me to resample using sample #6

Greg Fruchman

SAMPLE TYPE CODES

- | | |
|------------------------------|-------------------------------|
| 1 - Blank | 5 - Final Clearance (inside) |
| 2 - Pre-Abatement | 6 - Final Clearance (outside) |
| 3 - During Abatement | 7 - Personal |
| 4 - During Glove Bag Removal | 8 - Background |

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

CITY_21MC100_002991403