

ENVIRONMENTAL SERVICES INC.

TEM DEPARTMENT

CLIENT: WARREN & PANZER	DATE: 10/23/02
PROJECT: NYLDER/94 FULTON ST.	ANALYST: ES ES
BATCH #: T02-10-152	CLIENT ID #: 01
SAMPLE ID #: T02-10-152-3463	VOLUME (lt): 1500
G.O. AREA (mm ²): 0.013838	GO's TO ANALYZE: 4
MAGNIFICATION: 19K	ACC. VOLTAGE (KeV): 100
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ²): 0.0046	Eucentricity check :
Concentration (str/cm ²): 20.046	*Grid acceptance criteria check : (A).✓ (B)...✓
Concentration (str/mm ²): <18.07	**CHR. # STRUCT.: F M C B
Number of Asbestos Structures : 0.5<S<5µm ...0.	**AMPH. # STRUCT.: F M C B
S≥5µm0.	Specify AMPH. Type : AM. ACT. TRE.
Number of Non-asbestos Structures:.....0.	CRO. ANTH.

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite