

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: DEP W&P FILE #: _____
 PROJECT: NYU down town Hospital building LABORATORY: _____
 LOCATION: Gold Street elevation ANALYSIS METHOD: PCM TEM TEM
 circle one 7400 AHERA EPA LEVEL II
 TECHNICIAN: Mohamed

CONTACT: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)
01	on Emergency room roof, right side	3		5	5	0650	1148	298	1490	
02	on Emergency room roof, right	3		5	5	0652	1149	297	1485	
03	on emergency room, middle	3		5	5	0654	1150	296	1480	
04	on Emergency room roof left side	3		5	5	0657	1151	294	1470	
05	on emergency room roof left side	3		5	5	0658	1152	294	1470	
06	F-B	1								
07	F-B	1								
08	F-B / close	1								

COMMENTS:

T02-10-082

SAMPLE BY: Mohamed DATE: 10-13-02
 SIGNATURE: _____ 1PM
 RELEASED BY: _____ DATE: _____
 SIGNATURE: _____
 RECEIVED BY: E. Si... DATE: 10/14/02
 SIGNATURE: [Signature]

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

CITY_21MC100_003003652

A. INFORMATION FOR PCM ANALYSIS

1. Samples shall be analyzed using NIOSH 7400 method.
2. The laboratory performing the sample analysis must be accredited for PCM analysis by the AIHA or by the Department of Health pursuant to Section 502 of the Public Health Law (ELAP Certification).

B. INFORMATION FOR TEM ANALYSIS

1. For schools, clearance samples must be analyzed ny the AHERA method as per 40 CFR 763 Appendix A to Subpart E. The five inside samples shall be read first. If the five inside fail, then the five outside, two field blanks and one sealed blank shall be read.
2. For non-schools, clearance samples shall be read by EPA Level II. performed by the Yamate et al. Method.

C. GENERAL INFORMATION FOR BOTH PCM & TEM

1. All sample results shall include the name and address of the laboratory performing the analysis, the laboratory certification Number, the date of the analysis, the analytical method used, and the name and signature of the person performing the analysis.
2. The completed original (white) sheet of the CHAIN-OF-CUSTODY from should be returned to Warren & Panzer, the carbon (yellow) should be retained by the laboratory, and the pink copy should be retained by the field technician.
3. All air sample cassettes shall be returned to Warren & Panzer Engineers, P.C.
4. All invoices should be sent to Warren & Panzer Engineers, P.C., 228 East 45th Street 10th Floor New York, New York 10017 Attn: Accounts Payable. Please include W & P File # on all invoices.
5. Two (2) original copies of the laboratory results should be sent to Warren & Panzer Engineers, P.C., 228 East 45th Street 10th Floor New York, New York 10017

CITY_21MC100_003003653