



AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY


CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-10-015
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYCDEP, 24 John St.
DATE OF REPORT: 10/03/02
DATE OF ANALYSIS: 10/03/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (lt)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (struct./cm ³)	TOTAL ASBESTOS AIR CONC. (struc./cm ³)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR STRUCT. 0.5≤S<5μm	AIR CONC. FOR STRUCT. S≥5.0μm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST TYPE SPECIFY
01	T02-10-015-2755	IWA right side of WA (roof A)	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
02	T02-10-015-2756	IWA left side of WA (roof A)	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
03	T02-10-015-2757	IWA left side of WA (roof B)	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
04	T02-10-015-2758	IWA right side of WA (roof B)	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
05	T02-10-015-2759	Exit to the roof B	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA


ANALYST
E. Sioukri


LABORATORY DIRECTOR
Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.



ATHENICA

ENVIRONMENTAL SERVICES INC.

45-09 Greenpoint Avenue
Long Island City, N.Y. 11104

TEM DEPARTMENT

Tel. (718) 784-7490
Fax (718) 784-4085

TEM AHERA COUNTSHEET

CLIENT: Warren & Panzer	DATE: 10/3/02
PROJECT: NYCDOP/24 John Street	ANALYST: E.S.
BATCH #: T02-10-015	CLIENT ID #: 01
SAMPLE ID #: T02-10-015-2755	VOLUME (lt): 1680
G.O. AREA (mm ²): 0.013838	GO's TO ANALYZE: 4
MAGNIFICATION: 194	ACC. VOLTAGE (KeV): 100
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ³): 0.0041	Bucentricity check :
Concentration (str/cm ³): 0.0041	*Grid acceptance criteria check : (A)...✓(B)...✓
Concentration (str/mm ²): <18.07	**CHR. # STRUCT.: F M C B
Number of Asbestos Structures : 0.5 ≤ S < 5 μm ... 0...	**AMPH. # STRUCT.: F M C B
S ≥ 5 μm 0...	Specify AMPH. Type : AM. ACT. TRE.
Number of Non-asbestos Structures: 0...	CRO. ANTH.

* Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.

ATHENICA

ENVIRONMENTAL SERVICES INC.

45-09 Greenpoint Avenue
Long Island City, N.Y. 11104

TEM DEPARTMENT

Tel. (718) 784-7490
Fax (718) 784-4085

TEM AHERA COUNTSHEET

CLIENT: <i>Warren & Pamzer</i>	DATE: <i>10/3/02</i>
PROJECT: <i>NYCDEP/24 John Street</i>	ANALYST: <i>E.S.</i>
BATCH #: <i>T02-10-015</i>	CLIENT ID #: <i>02</i>
SAMPLE ID #: <i>T02-10-015-2756</i>	VOLUME (lit): <i>1680</i>
G.O. AREA (mm ²): <i>0.013838</i>	GO's TO ANALYZE: <i>4</i>
MAGNIFICATION: <i>194</i>	ACC. VOLTAGE (KeV): <i>100</i>
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): <i>385</i>
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

GRI D	GO ID	Str. #	Str. Classf.	L (μm)	W (μm)	Structure sketch	SAE D	EDXA	PHO TO#	ID
A	G4	NSD								
	E8	NSD								
B	B6	NSD								
	E5	NSD								

Analytical Sensitivity (str/cm ²): <i>0.0041</i>	Eucentricity check: ☒
Concentration (str/cm ²): <i><0.0041</i>	*Grid acceptance criteria check: (A) ☒ (B) ☒
Concentration (str/mm ²): <i><18.07</i>	**CHR. # STRUCT.: F M C B
Number of Asbestos Structures: <i>0.5 ≤ S < 5 μm .. 0..</i>	**AMPH. # STRUCT.: F M C B
<i>S ≥ 5 μm 0..</i>	Specify AMPH. Type: AM ACT TRE
Number of Non-asbestos Structures: <i>..... 0..</i>	CRO ANTH.

* Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.

Tel. (718) 784-7490
Fax (718) 784-4085

CLIENT: <i>Warren & Panzer</i>	DATE: <i>10/3/02</i>
PROJECT: <i>NYCDEP/24 John Street</i>	ANALYST: <i>E.S.</i>
BATCH #: <i>T02-10-015</i>	CLIENT ID #: <i>03</i>
SAMPLE ID #: <i>T02-10-015-2757</i>	VOLUME (lt): <i>1680</i>
G.O. AREA (mm ²): <i>0.013838</i>	GO's TO ANALYZE: <i>4</i>
MAGNIFICATION: <i>194</i>	ACC. VOLTAGE (KeV): <i>100</i>
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): <i>385</i>
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ³):	0.0041	Eucentricity check:	
Concentration (str/cm ³):	20.0041	*Grid acceptance criteria check:	(A)..... (B).....
Concentration (str/mm ³):	218.07	**CHR. # STRUCT.:	F M C B
Number of Asbestos Structures:	0.5 ≤ S < 5 μm 0	**AMPH. # STRUCT.:	F M C B
	S ≥ 5 μm 0	Specify AMPH. Type:	AM. ACT. TRE.
Number of Non-asbestos Structures:	 0	CRO. ANTH.	

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.



ATHENICA

ENVIRONMENTAL SERVICES INC.

45-09 Greenpoint Avenue
Long Island City, N.Y. 11104

TEM DEPARTMENT

Tel. (718) 784-7490
Fax (718) 784-4085

TEM AHERA COUNTSHEET

CLIENT: <i>Warren & Panzer</i>	DATE: <i>10/3/02</i>
PROJECT: <i>NYCDEP/24 John Street</i>	ANALYST: <i>E.S.</i>
BATCH #: <i>T02-10-015</i>	CLIENT ID #: <i>04</i>
SAMPLE ID #: <i>T02-10-015-2758</i>	VOLUME (lit): <i>1680</i>
G.O. AREA (mm ²): <i>0.013838</i>	GO's TO ANALYZE: <i>4</i>
MAGNIFICATION: <i>194</i>	ACC. VOLTAGE (KeV): <i>100</i>
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): <i>385</i>
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

GRI D	GO ID	Str. #	Str. Classf.	L (μm)	W (μm)	Structure sketch	S&E D	EDXA	PHO TO#	ID
A	D4	NSD								
	G7	NSD								
B	HS	1	F	2.7	0.1		NA			NA
	B4	NSD								

Analytical Sensitivity (str/cm ³): <i>0.0041</i>	Eucentricity check: ☒
Concentration (str/cm ³): <i>< 0.0041</i>	*Grid acceptance criteria check: (A) ☒ (B) ☒
Concentration (str/mm ²): <i>< 18.07</i>	**CHR. # STRUCT.: F <i>00</i> M <i>0</i> C <i>0</i> B <i>0</i>
Number of Asbestos Structures: <i>0.5 ≤ S < 5 μm: 0.0</i>	**AMPH. # STRUCT.: F <i>0</i> M <i>0</i> C <i>0</i> B <i>0</i>
<i>S ≥ 5 μm: 0</i>	Specify AMPH. Type: AM. ACT. TRE.
Number of Non-asbestos Structures: <i>0</i>	CRO. ANTH.

* Replica covers >50%, at least 20 GO's with no overlapping or folded replica, intact GO's have >50% coverage, <50% Undissolved filter, <5% holes or opaque areas, <10% particulate coverage.

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.

