

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7480
Fax (718) 784-4085

CLIENT: WARREN & PANZER	DATE: 10/13/02
PROJECT: NYC DEP/55 NASSAU ST.	ANALYST: E.S.
BATCH #: T02-16-075	CLIENT ID #: 01
SAMPLE ID #: T02-10-075-3061	VOLUME (l): 1440
G.O. AREA (mm ²): 0.013838	GO's TO ANALYZE: 4
MAGNIFICATION: 19K	ACC. VOLTAGE (KeV): 100
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ³):	0.0048	Bucentricity check :	
Concentration (str/cm ³):	<0.0048	*Grid acceptance criteria check :	(A).....(B).....
Concentration (str/mm ²):	<18.07	**CHR. # STRUCT.:	F M C B
Number of Asbestos Structures :	0.5 ≤ S < 5 μm 0	**AMPH. # STRUCT.:	F M C B
	S ≥ 5 μm 0	Specify AMPH. Type :	AM. ACT. TRE.
Number of Non-asbestos Structures:	 0	CRO. ANTH.	

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.