

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/22/02

11:00:00 PM

ATC Group #: 8231

Analysis Date: 6/23/02

Project: NYC-DEP W & P File #: 1079.01.02

26 Wall Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
JB62202-1 8231 -1	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
JB62202-2 8231 -2	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
JB62202-3 8231 -3	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
JB62202-4 8231 -4	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
JB62202-5 8231 -5	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
JB62202-6 8231 -6	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
JB62202-7 8231 -7	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/22/02 11:00:00 PM
 ATC Group #: 8231
 Analysis Date: 6/23/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 26 Wall Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
JB62202-8 8231 -8	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	
JB62202-9 8231 -9	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	
JB62202-10 8231 -10	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879