

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/27/02 8:00:00 PM
ATC Group #: 8315
Analysis Date: 6/28/02

Fax: (212) 922-0630 **Phone:** (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 63 Wall Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
001 8315 -1	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
002 8315 -2	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
003 8315 -3	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
004 8315 -4	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
005 8315 -5	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
009 8315 -6	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
010 8315 -7	1310.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879