

**ATC Associates**

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



**Attn:** Mr. Fabio Pedone  
 Warren & Panzer Engineers, P.C.  
 228 E. 45th Street  
 New York NY 10017

**Received:** 7/13/02 7:15:00 PM  
**ATC Group #:** 8489  
**Analysis Date:** 7/14/02

**Fax:** (212) 922-0630 **Phone:** (212) 922-0077

**Project:** NYC DEP, W&P# 1079.01.02  
 26 Warren Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed  
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

| Sample        | Volume  | Area<br>Analyzed | Non<br>Asb | Asbestos<br>Type(s) | # Structures |    | Analytical<br>Sensitivity<br>(S/cc) | Asbestos<br>Concentration |         | Notes |
|---------------|---------|------------------|------------|---------------------|--------------|----|-------------------------------------|---------------------------|---------|-------|
|               |         |                  |            |                     | 0.5µ-5       | 5µ |                                     | (S/mm <sup>2</sup> )      | (S/cc)  |       |
| 01<br>8489 -1 | 2160.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0040                              | <22.24                    | <0.0040 |       |
| 02<br>8489 -2 | 2160.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0040                              | <22.24                    | <0.0040 |       |
| 03<br>8489 -3 | 2160.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0040                              | <22.24                    | <0.0040 |       |
| 04<br>8489 -4 | 2160.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0040                              | <22.24                    | <0.0040 |       |
| 05<br>8489 -5 | 2160.00 | 0.0450           | 0          | None Detected       | 0            | 0  | 0.0040                              | <22.24                    | <0.0040 |       |

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm<sup>2</sup>. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879