NYC 9/11 Public Portal Document

TESTWELL LABORATORIES, INC.
Environmental Laboratory
47 Hudson Street, Ossining, New York 10562

NYS ELAP # 11142
NVLAP # 200083-0
AIHA # 100147

Transmission Electron Microscopy Results

Client: **Warren & Panzer Engineers, P.C.**
228 East 45th Street
New York, NY 10017

Sample Location: NYC DEP
Side Facades
30 W Broadway

Field Technician: Client

Filter Type: MCE 0.45 micron
Avg.Grid Opening: 0.0121mm²

Project #: NUF-001AB

Date Collected: 07/25/02
Date Rec'd (lab): 07/26/02
Analysis Date: 07/30/02
TEM Analyst: *D. McCarl*
Analytical Method: **AHERA**

Sample #:	Sample Location:	Lab Number 02TEM #	Volume Coll. (liters)	Grid Openings Analyzed	Grid Area Analyzed	Countable Asb. Structures	Concentration Structures/mm²	Concentration Structures/cc
01	By Entrance	5228	1440.0	5	0.061	0	**<16.53**	**<0.004**
02	By Decon	5229	1440.0	5	0.061	0	**<16.53**	**<0.004**
03	Inside Work Area West	5230	1440.0	5	0.061	0	**<16.53**	**<0.004**
04	Inside Work Area Center	5231	1440.0	5	0.061	0	**<16.53**	**<0.004**
05	Inside Work Area East	5232	1440.0	5	0.061	0	**<16.53**	**<0.004**
06	BF	5233	0.0	N/A	0.048	N/A	**N/A**	**N/A**
07	BF	5234	0.0	N/A	0.048	N/A	**N/A**	**N/A**
08	Copped Blank	5235	0.0	N/A	0.048	N/A	**N/A**	**N/A**
							Structures/mm²	Structures/cc²
				Total Average Concentrations			**<16.53**	**<0.004**

This report is the confidential property of our clients. This certificate of analysis/report shall not be used by the client to claim product endorsement by the National Voluntary Laboratory Approval Program (NVLAP) or any agency of the United States Government. The laboratory has no control over air sampling collection. This certificate of analysis/report shall not be reproduced in full, without the written approval of Testwell Laboratories, Inc.
Copyright © 2002 Testwell Laboratories, Inc.

Laboratory Director/Approved Signatory