

Address: 80 GOLD (BLDG #1)

Bulk Samples PLM ☒ Yes ☐ No

Number of Negative ($\leq 1\%$) Samples 3 // ("oo")

Number of Positive ($> 1\%$) Samples 0

NOTE: BULK PLM SAMPLES WERE VIA "WIDE DUST" AND NO ASBESTOS TO LISTED, JUST "NO VISIBLE ASBESTOS"

* ALSO DID BULK TEM ANALYSIS AS FOLLOWS:

Air Samples ☒ Yes ☐ No

5 - "NO VISIBLE ASBES."
2 - "CHRISTOPHLE PRESENT"

PCM

Number of Samples Collected (≤ 0.01 f/cc) _____

Number of Samples Collected (> 0.01 f/cc) _____

TEM

Number of Samples Collected (≤ 70 s/mm²) 3 // (181)

Number of Samples Collected (> 70 s/mm²) 0 // (1011)

INTERIOR DEBRIS - NOT INDICATED

GENERAL CLEAN-UP " "

ACM CLEANUP " "