NYC 9/11 Public Portal Document

Address: 90 COLD (BLDG 4)

Bulk Samples PLM (Yes) No

Number of Negative (≤ 1 %) Samples 3

Number of Positive (> 1%) Samples 0

NOTE: BULK PLM SAMPLES WERE VIA "WIPE DUST" AND NO ASBESTOS 90 LISTED, JUST "NO VISIBLE ASBESTOS" * ALSO DID BULK TEM ANALYSIS AS FOLLOWS; 11- "NO VISIBLE ASBESTOS"

Air Samples (Yes) No

PCM

Number of Samples Collected (≤ 0.01f/cc) _____

Number of Samples Collected (>0.01 f/cc) _____

TEM

Number of Samples Collected (≤ 70 s/mm^2) 2 11 (10-11)

Number of Samples Collected (>70 s/mm^2) 0

INTERIOR DEBRIS NOT INDICATED

GENERAL CLEAN-UP " "

ACM CLEANUP " "