NYC 9/11 Public Portal Document

Address: 41-51 CHURCH ST. AKA 172-184 FULTON (MILLEN-IUM HOTEL)

Bulk Samples PLM (Yes) No

Number of Negative (≤ 1 %) Samples 150-

Number of Positive (> 1%) Samples 9-

Air Samples (Yes) No

PCM

Number of Samples Collected (≤ 0.01f/cc) 4- IIII

Number of Samples Collected (>0.01 f/cc) 8- ~~HH~~ III

TEM

Number of Samples Collected (≤ 70 s/mm²) 92-

Number of Samples Collected (>70 s/mm²) 85-

NOTE: ALSO DID TEM ANALY. (11-1/9-01) ON 35- DUST SAMPLES - SEE LAB REPORTS; FOR CONCENTRATION IN S/CM²

INTERIOR DEBRIS - YES (BOULDER 2-22-02)

GENERAL CLEAN-UP - YES

ACM CLEANUP - YES (BOULDER 2-22-02)

OVER

NYC-WTC_000206779

NYC 9/11 Public Portal Document

NOTE:

CONSULTANT ALSO ~~REPORTED A~~ PERFORMED A SERIES OF ANALYSES, MOSTLY ON ALL DUST 9-11-02, ON VARIOUS AREAS OF BLDG FOR TO DETERMINE 8 HR TWA ETC. (ANALYSIS METHODOLOGY NOT STATED) IN f/cc.

SEE REPORT FOR ADDITIONAL DETAILS (DATED 10-16-01 BY TESTWELL LABS)

NYC-WTC_000206780