

YARBROUGH INC

PHONE NO. : 2128689293

Apr. 18 2002 10:44AM P11

SCI LAB

SCIENTIFIC LABORATORIES, INC.

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9382

PLM Bulk Asbestos Report

LeRoy G. Shaw Associates
Attn: LeRoy Shaw
618 Baker Ave.
Bronx, NY 10460

Date Received 04/13/2002 SciLab Job No. 202042274
Date Examined 04/13/2002 P.O. # Shaw
ELAP Number 11480 Page 1 of 1
RE:

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
RQ-1	202042274-01	Yes	<1.2 %

Location: Roof

Description: Grey, Heterogeneous, Bulk Material
Asbestos Types: Chrysotile Trace
Other Material: Animal hair Trace, Cellulose 5. %, Fibrous glass 30. %, Synthetic fibers Trace, Non-fibrous 65. %

3-8	202042274-02	Yes	10 %
-----	--------------	-----	------

Location: Roof

Description: Black, Homogeneous, Bulk Material
Asbestos Types: Chrysotile 10. %
Other Material: Cellulose Trace, Non-fibrous 90. %

3-A2	202042274-03	Yes	11 %
------	--------------	-----	------

Location: Roof

Description: Black, Homogeneous, Bulk Material
Asbestos Types: Chrysotile 11. %
Other Material: Cellulose Trace, Fibrous glass Trace, Non-fibrous 89. %

Reporting Notes:

- (1) Composite result for analysis of heterogeneous debris sample.
- (2) Composite analysis results for heterogeneous debris samples may be highly variable due to inhomogenities in materials present

Analyzed by: Jonathan Teda

*NAD/NSD = no asbestos detected; NA = not analyzed; NA/PS = not analyzed / positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab #200546-0) and ELAP PLM Analysis Protocol 198.1 for New York samples (NYSDOH ELAP Lab # 11480); Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (also see EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the laboratory. This PLM report relates ONLY to the items tested. AIHA# 102843; VT Cert# ALO16055

Reviewed By:

8/11/18 2626 679 9392

SCIENTIFIC LABS

APR-13-2002 18:29

CITY_21MC100_003011367