

**NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WASTEWATER TREATMENT**

LIMITATIONS FOR EFFLUENT TO *STORM* SEWERS

Parameter	Daily Limit	Units	Sample Type	Monthly Limit
Oil & Grease	15	mg/l	Instantaneous	
pH (range)	6.5-8.5	SU's	Instantaneous	
Benzene	134	ppb	Instantaneous	57
Ethylbenzene	380	ppb	Instantaneous	142
Toluene	74	ppb	Instantaneous	28
Xylenes (Total)	74	ppb	Instantaneous	28
Temperature	<150	degrees F	Instantaneous	
Cadmium	2 0.69	mg/l mg/l	Instantaneous Composite	
Chromium (VI)	5	mg/l	Instantaneous	
Copper	5	mg/l	Instantaneous	
Lead	2	mg/l	Instantaneous	
Mercury	0.05	mg/l	Instantaneous	
Nickel	3	mg/l	Instantaneous	
Zinc	5	mg/l	Instantaneous	
Flash Point	>140	degrees F	Instantaneous	
Total Suspended Solids	No Limit		Instantaneous	
PCB's (Total)*	1	ppb	Composite	
Perc (Tetrachloroethylene)	20	ppb	Instantaneous	
MTBE (Methyl-Tert-Butyl-Ether)	10	ppb	Instantaneous	10
Naphthalene	47	ppb	Composite	19
Other				

* Analysis for PCB's are requested ***only*** if ***both*** conditions listed below are met:

- 1) if proposed discharge > 10,000 gpd;
- 2) if duration of a discharge > 10 days.

Analysis for PCB's must be done by method 608 by EPA only with MDL=65 ppt