

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/23/02 2:00:00 PM

ATC Group #: 8240

Analysis Date: 6/23/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
1 8240 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
2 8240 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
3 8240 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
4 8240 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
5 8240 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
6 8240 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
7 8240 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/23/02 2:00:00 PM
 ATC Group #: 8240
 Analysis Date: 6/23/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
8 8240 -8	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
9 8240 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 8240 -10	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
11 8240 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 8240 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 8240 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 8240 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 8240 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
16 8240 -16	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0; NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/23/02 2:00:00 PM
 ATC Group #: 8240
 Analysis Date: 6/23/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
17 8240 -17	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
18 8240 -18	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
19 8240 -19	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
20 8240 -20	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
21 8240 -21	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879