

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: NYC-BOE PS 42M Project #: 14584-871

71 Hester Street, New York, NY.

Received: 9/5/02

8:00:00 AM

ATC Group #: 8809

Analysis Date: 9/5/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
01 8809 -1	1920.00	0.0450	0	None Detected	0	0.0045	<22.24	<0.0045
02 8809 -2	1920.00	0.0450	0	None Detected	0	0.0045	<22.24	<0.0045
03 8809 -3	1920.00	0.0450	0	None Detected	0	0.0045	<22.24	<0.0045
04 8809 -4	1920.00	0.0450	0	None Detected	0	0.0045	<22.24	<0.0045
05 8809 -5	1928.00	0.0450	0	None Detected	0	0.0044	<22.24	<0.0044
06 8809 -6	1928.00	0.0450	0	None Detected	0	0.0044	<22.24	<0.0044
07 8809 -7	1920.00	0.0450	0	None Detected	0	0.0045	<22.24	<0.0045

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/5/02 8:00:00 AM
 ATC Group #: 8809
 Analysis Date: 9/5/02


Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 42M Project #: 14584-871
 71 Hester Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
08 8809 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
09 8809 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 8809 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
11 8809 -11	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 8809 -12	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
13 8809 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
14 8809 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 8809 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 8809 -16	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/5/02 8:00:00 AM
 ATC Group #: 8809
 Analysis Date: 9/5/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: NYC-BOE PS 42M Project #: 14584-871
 71 Hester Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
17 8809 -17	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
18 8809 -18	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879