

Sep 23 02 09:36a

PSC

610-921-9667

p. 9



INDUSTRIAL HYGIENE

ENVIRONMENTAL TESTING

• EPA NVLAP 101262-0
• AIHA ACCREDITATION NO 100439
• NC DENR 599

• NY DOH/NELAC 10903
• PA DEP 06-363

• NJ DEP PA020
• CT DPH PH-0238

Analytical Results
for

ATC Associates

WorkOrder: R02090431

Client Reference: P.S. 124 M

Analyte	Concentration			Limit of Detection (ug)	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m ³)	(ppm)			

Client ID: ATC-0912-124M-M2 *Leaky Main E.H.W.* Lab ID: -01A Date Sampled: 9/12/02 Matrix: Filter Air Vol.(L): 1200

Aluminum	<1.00	<0.000833	--	1	N7300 MCE	09/14/2002 AJB
Cadmium	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Chromium	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Cobalt	<0.100	<0.0000833	--	0.1	N7300 MCE	09/14/2002 AJB
Copper	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Iron	<2.00	<0.00167	--	2	N7300 MCE	09/14/2002 AJB
Lead	<0.300	<0.000250	--	0.3	N7300 MCE	09/14/2002 AJB
Magnesium	<1.30	<0.00108	--	1.3	N7300 MCE	09/14/2002 AJB
Manganese	<0.300	<0.000250	--	0.3	N7300 MCE	09/14/2002 AJB
Molybdenum	<1.00	<0.000833	--	1	N7300 MCE	09/14/2002 AJB
Nickel	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Zinc	<0.500	<0.000417	--	0.5	N7300 MCE	09/14/2002 AJB

Client ID: ATC-0912-124M-M2 *Leaky Main E.H.W.* Lab ID: -02A Date Sampled: 9/12/02 Matrix: Filter Air Vol.(L): 1200

Aluminum	<1.00	<0.000833	--	1	N7300 MCE	09/14/2002 AJB
Cadmium	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Chromium	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Cobalt	<0.100	<0.0000833	--	0.1	N7300 MCE	09/14/2002 AJB
Copper	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Iron	<2.00	<0.00167	--	2	N7300 MCE	09/14/2002 AJB
Lead	<0.300	<0.000250	--	0.3	N7300 MCE	09/14/2002 AJB
Magnesium	<1.30	<0.00108	--	1.3	N7300 MCE	09/14/2002 AJB
Manganese	<0.300	<0.000250	--	0.3	N7300 MCE	09/14/2002 AJB
Molybdenum	<1.00	<0.000833	--	1	N7300 MCE	09/14/2002 AJB
Nickel	<0.200	<0.000167	--	0.2	N7300 MCE	09/14/2002 AJB
Zinc	<0.500	<0.000417	--	0.5	N7300 MCE	09/14/2002 AJB

Sep 23 02 09:37a

PSC

610-921-9667

p. 10



INDUSTRIAL HYGIENE

ENVIRONMENTAL TESTING

• EPA/NVLAP 101262-0
 • AIHA ACCREDITATION NO 100439
 • NC DENR 599

• NY DOH/NELAC 10903
 • PA DEP 06-353

• NJ DEP PA020
 • CT DPH PH-0238

Analytical Results
 for

ATC Associates

WorkOrder: R02090431

Client Reference: P.S. 124 M

Analyte	Concentration			Limit of Detection (ug)	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m ³)	(ppm)			

Client ID: ATC-0912-124M-M3 *3rd fl Hall by Room 207* Lab ID: -03A Date Sampled: 9/12/02 Matrix: Filter Air Vol.(L): 1200

Aluminum	<1.00	<0.000833	--	1	N7300 MCE	09/19/2002	AJB
Cadmium	<0.200	<0.000167	--	0.2	N7300 MCE	09/19/2002	AJB
Chromium	<0.200	<0.000167	--	0.2	N7300 MCE	09/19/2002	AJB
Cobalt	<0.100	<0.0000833	--	0.1	N7300 MCE	09/19/2002	AJB
Copper	<0.200	<0.000167	--	0.2	N7300 MCE	09/19/2002	AJB
Iron	<2.00	<0.00167	--	2	N7300 MCE	09/19/2002	AJB
Lead	<0.300	<0.000250	--	0.3	N7300 MCE	09/19/2002	AJB
Magnesium	<1.30	<0.00108	--	1.3	N7300 MCE	09/19/2002	AJB
Manganese	<0.300	<0.000250	--	0.3	N7300 MCE	09/19/2002	AJB
Molybdenum	<1.00	<0.000833	--	1	N7300 MCE	09/19/2002	AJB
Nickel	<0.200	<0.000167	--	0.2	N7300 MCE	09/19/2002	AJB
Zinc	<0.500	<0.000417	--	0.5	N7300 MCE	09/19/2002	AJB

Client ID: ATC-0912-124M-M4 *Blank* Lab ID: -04A Date Sampled: 9/12/02 Matrix: Filter Air Vol.(L): NA

Aluminum	<1.00	--	--	1	N7300 MCE	09/19/2002	AJB
Cadmium	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Chromium	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Cobalt	<0.100	--	--	0.1	N7300 MCE	09/19/2002	AJB
Copper	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Iron	<2.00	--	--	2	N7300 MCE	09/19/2002	AJB
Lead	<0.300	--	--	0.3	N7300 MCE	09/19/2002	AJB
Magnesium	<1.30	--	--	1.3	N7300 MCE	09/19/2002	AJB
Manganese	<0.300	--	--	0.3	N7300 MCE	09/19/2002	AJB
Molybdenum	<1.00	--	--	1	N7300 MCE	09/19/2002	AJB
Nickel	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Zinc	<0.500	--	--	0.5	N7300 MCE	09/19/2002	AJB

Sep 23 02 09:37a

PSC

610-921-9667

p. 11



INDUSTRIAL HYGIENE

ENVIRONMENTAL TESTING

• EPA NVLAP 101262-D
 • AIHA ACCREDITATION NO 100439
 • NC DENR 599

• NY DOH/NELAC 10903
 • PA DEP 06-353

• NJ DEP PAD20
 • CT DPH PH-0238

**Analytical Results
for**

ATC Associates

WorkOrder: R02090431

Client Reference: P.S 124 M

Analyte	Concentration			Limit of Detection (ug)	Test Method	Date Analyzed /Analyst	
	(ug)	(mg/m³)	(ppm)				
Client ID: ATC-0912-124M-M5		Lab ID: -05A	Date Sampled: 9/12/02		Matrix: Filter		Air Vol.(L): NA
Aluminum	<1.00	--	--	1	N7300 MCE	09/19/2002	AJB
Cadmium	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Chromium	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Cobalt	<0.100	--	--	0.1	N7300 MCE	09/19/2002	AJB
Copper	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Iron	<2.00	--	--	2	N7300 MCE	09/19/2002	AJB
Lead	<0.300	--	--	0.3	N7300 MCE	09/19/2002	AJB
Magnesium	<1.30	--	--	1.3	N7300 MCE	09/19/2002	AJB
Manganese	<0.300	--	--	0.3	N7300 MCE	09/19/2002	AJB
Molybdenum	<1.00	--	--	1	N7300 MCE	09/19/2002	AJB
Nickel	<0.200	--	--	0.2	N7300 MCE	09/19/2002	AJB
Zinc	<0.500	--	--	0.5	N7300 MCE	09/19/2002	AJB

(a) Analysis indicates possible breakthrough; back section result is greater than 0% of the front section result

General Notes:

<: Less than the indicated limit of detection (LOD).

--: Information not available or not applicable.

Back sections were checked and showed no significant breakthrough.