

01/23/2002 15:09 FAX 212 353 8306

ATC

JAN 16 2002 14:26 FR SCILAB BOSTON

781 337 7642 TO 12123538306

005
P.02/05

Eight School Street
Weymouth, MA 02189
781-337-9334

Laboratory Report

Customer: ATC Associates
104 East 25th Street
New York, NY 10010

Report Date 1/16/02
Workorder No. 0201-00106

Attention: Andreas Andreou
Subject: M833: POTABILITY

Sample: 001 M833-1/14-1P: 10TH FLOOR HALLWAY
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	1.96	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	23	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.06	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	143.2	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 002 M833-1/14-2P: 9TH FLOOR HALLWAY
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	2.30	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	26	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.05	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	140.4	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 003 M833-1/14-3P: 8TH FLOOR KITCHEN
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	1.06	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	16	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	

Certifications: MA: MA069 NY:10982 CT: PH0119 RE:A45 CA:2050 ME:MA069 NJ: 59744

Page: 1 of 3

CITY_21MC100_003018398

01/23/2002 15:09 FAX 212 353 8306

ATC

781 337 7642 TO 12123538306

0008
P.03/05

JAN 16 2002 14:27 FR SCILAB BOSTON



Customer: ATC Associates

Workorder No. 0201-00106

Sample: 003 M833-1/14-3P: 8TH FLOOR KITCHEN
(Continued)

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
pH	4500-H-B SM 18TH, 1	7.06	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	121.8	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 004 M833-1/14-4P: 8TH FLOOR CAFETERIA
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	2.31	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	23	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.16	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	136.7	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 005 M833-1/14-5P: 6TH FLOOR HALLWAY
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	1.97	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	20	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.16	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	124.5	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 006 M833-1/14-6P: 3RD FLOOR HALLWAY
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	2.84	NTU	1	SG	01/15/02	

Certifications: MA: MA069 NY:10982 CT: PH0119 RI:A45 CA:2050 ME:MA069 NJ: 59744

Page: 2 of 3

CITY_21MC100_003018399

01/23/2002 15:09 FAX 212 353 8306

ATC

781 337 7642 TO 12123538306

0007
P. 04/05

JAN 16 2002 14:27 FR SCILAB BOSTON



Customer: ATC Associates

Workorder No. 0201-00106

Sample: 006 M833-1/14-6P: 3RD FLOOR HALLWAY
(Continued)


Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Color	2120C SM 18TH, 1992	27	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.15	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	120.1	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

Sample: 007 M833-1/14-7P: 2ND FLOOR HALLWAY
Date: 1/14/02
Matrix: WATER

Parameter	Method	Results	Units	PQL	Analyst	Analysis Date	Qual
Turbidity	2540D SM 18TH, 199	1.37	NTU	1	SG	01/15/02	
Color	2120C SM 18TH, 1992	16	Cu	5	SG	01/15/02	
Odor	2150 SM 18TH, 1992	ND	ton	1	SMH	01/15/02	
pH	4500-H-B SM 18TH, 1	7.08	S.U.	0	SMH	01/15/02	
Conductivity	2510B SM 18TH, 1992	122.5	umho/cm	0	SG	01/16/02	
Free Residual Chlorine	408D, SM 16TH ED	ND	mg/L	0.1	SMH	01/15/02	

To the best of my knowledge this report is true and accurate.

Authorized By:


John J. Sulkowski, Laboratory Director

Certifications: MA: MA069 NY: 10982 CT: PH0119 RI: A45 CA: 2050 ME: MA069 NJ: 59744

Page: 3 of 3

CITY_21MC100_003018400