NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: NYC-BOE HS Of Econ & Finance
100 Trinity Pl. Nyw York, NY. Project#:14584-0865

Received: 1/25/02 6:00:00 AM

ATC Group #: 6432

Analysis Date: 1/25/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5μ-5	Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
M833-4 6432 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
M833-5 6432 -2	1464.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047	
M833-6 6432 -3	1416.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
M833-7 6432 -4	1304.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
M833-8 6432 -5	1280.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
M833-9 6432 -6	1264.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
M833-10 6432 -7	1248.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
M833-11 6432 -8	1240.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0. NY State ELAP #10879

NYC-WTC_000208031

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 Phone: (212) 477-8941

Received: 1/25/02 6:00:00 AM
ATC Group #: 6432
Analysis Date: 1/25/02

Project: NYC-BOE HS Of Econ & Finance
100 Trinity Pl. Nyw York, NY. Project#:14584-0865

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5	Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
M833-12 6432 -9	1248.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
M833-13 6432 -10	1288.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

NYC-WTC_000208032