

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/4/02 4:35:00 PM
 ATC Group #: 7633
 Analysis Date: 5/4/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 150M Project#: 14584-0824
 334 Greenwich St., New York, NY. 10013

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
01 7633 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 7633 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 7633 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 7633 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 7633 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 7633 -6	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
07 7633 -7	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

