

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6

LOCATION Various school buildings

DATE 2/28/02 PROJECT NO. 19125 - 0314

Location	Time	PM10 (µg/m³)	PM2.5 (µg/m³)
ATC OFFICE 104 E 25 th 11 th Floor	0555	3	2
ATC OFFICE 104 E 25 th Outside Bldg	0600	0	9
PS 874M - 55 E 25 th Lobby	0612	2	5
PS 874M - 55 E 25 th Outside School	0615	0	7
PS 11M - 320 W 21 st Lobby/Cafeteria	0625	1	10
PS 11M 320 W 21 st Outside School	0630	0	12
PS 70M - 333 W 17 th Lobby	0638	2	6
PS 70M - 333 W 17 th Outside School	0642	0	11
PS 41M 116 W 11 th Lobby	0700	2	6
PS 41M 116 W 11 th Outside School	0705	0	8
Guideline levels ASHRAE/AIHA/EPA			65 µg/m³ 24-hour average

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/28/02

CITY_21MC100_003020874

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

LOCATION Various school buildings

DATE 2/28/02 PROJECT NO. 19125 - 0314

Location	Time	CO ₂ (ppm)	Particulate Matter (µg/m ³)
PS 3M 490 Hudson St LOBBY	0720	4	6
PS 3M 490 Hudson St. Outside School	0725	0	9
St. Bernard School 327 W 13 th Outside School	0737	0	9
LEGACY HS. 34 W. 14 th 14 th FL LOBBY	0750	7	6
LEGACY HS 34 W. 14 th Outside School	0755	0	50
PS 226 M (870 M) 12 W 12 th LOBBY	0802	6	10
PS 226 M (870 M) 12 W 12 th Outside School	0807	0	12
PS 60 M 420 E 12 th LOBBY/CAFETERIA	0825	50	13
PS 60 M 420 E 12 th Outside School	0830	5	15
Guideline levels ASHRAE/AIHA/EPA			65 µg/m ³ 24-hour average

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: J. Driscoll Date: 2/28/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6

LOCATION Various school buildings

DATE 2/25/02 PROJECT NO. 19125 - 0314

Location	Time	PM10	PM2.5
PS 61M 610 E. 12 ST LOBBY	0840	40	22
PS 61M 610 E 12 ST Outside School	0845	3	10
PS 34M 730 E 12 ST LOBBY	0852	12	14
PS 34M 730 E 12 ST Outside School	0858	3	16
PS 19M 185 1 ST AVE LOBBY	0915	6	10
PS 19M 185 1 ST AVE Outside School	0920	5	14
PS 64M 600 E 6 ST LOBBY	09:28	3	11
PS 64M 600 E 6 ST Outside School	09:33	2	12
PS 15M 333 E 4 ST LOBBY	09:40	5	13
PS 15M 333 E 4 ST Outside School	09:45	0	11
Guideline levels ASHRAE/AIHA/EPA			65 µg/m³ 24-hour average

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: JL Beaulieu Date: 2/28/02

CITY_21MC100_003020876

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4

LOCATION Various school buildings

DATE 2/28/02 PROJECT NO. 19125 - 0314

Location	Time	PM10	PM2.5
PS63M - 121E 3 rd LOBBY/CAFETERIA	09:50	12	14
PS63M - 121E 3 rd OUTSIDE SCHOOL	09:55	0	17
H.S. OF PREF. + HUMAN SERVICES 345E 15 th LOBBY	10:00	11	13
H.S. OF PREF. + HUMAN SERVICES 345E 15 th OUTSIDE SCHOOL	10:05	4	14
PS40M 319E 20 th LOBBY	10:10	2	13
PS40M 319E 20 th OUTSIDE SCHOOL	10:15	0	16
JHS 104-330E 26 th LOBBY	10:20	15	11
JHS 104 330E 26 th OUTSIDE SCHOOL	10:25	0	13
PS47M-225E 23 rd LOBBY	10:50	5	14
PS47M-225E 23 rd OUTSIDE SCHOOL	10:55	0	25
Guideline levels ASHRAE/AIHA/EPA			65 µg/m³ 24-hour average

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

CITY_21MC100_003020877

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

LOCATION Various school buildings

DATE 2/28/02 PROJECT NO. 19125 - 0314

H.S. OF the Future 127 E 22 ST LOBBY	11:05	15	25
H.S. OF the Future 127 E 22 ST Outside School	11:10	0	37
PS 116 - 210 E. 33 ST LOBBY	11:50	14	19
PS 116 210 E. 33 ST Outside School	11:55	0	13
NORMAN THOMAS HS. 111 E. 33 ST LOBBY	12:05	12	14
NORMAN THOMAS HS. 111 E. 33 ST Outside School	12:10	0	18
JHS 22M - 111 COLUMBIA ST. B-LOBBY	12:45	4	10
JHS 22M - 111 COLUMBIA ST. Outside School	12:50	0	12
JHS-56M - 220 HENRY ST. LOBBY	13:00	12	10
JHS-56M - 220 HENRY ST. Outside School	13:05	0	14
Guideline levels ASHRAE/AIHA/EPA			65 µg/m³ 24-hour average

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: J. L. Scallan Date: 2/28/02

CITY_21MC100_003020878

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6

LOCATION Various school buildings

DATE 2/28/02 PROJECT NO. 19125 - 0314

Location	Time	Occup.	Respirable Particulates($\mu\text{g}/\text{m}^3$)
PS 2M 122 HENRY ST. LOBBY	1310	13	15
PS 2M 122 HENRY ST. OUTSIDE SCHOOL	1315	0	19
PS 1M 8 HENRY ST. LOBBY/CAFETERIA	1330	22	20
PS 1M 8 HENRY ST. OUTSIDE SCHOOL	1335	0	16
PS 130M 143 BAXTER ST. LOBBY	21420	8	9
PS 130M 143 BAXTER ST. OUTSIDE SCHOOL	1430	3	15
PS 131M 100 HESTER ST. LOBBY	1445	24	17
PS 131M 100 HESTER ST. OUTSIDE SCHOOL	1455	0	19
PS 41M 116 W. 115 TH ST. LOBBY	1545	9	10
PS 41M 116 W. 115 TH ST. OUTSIDE SCHOOL	1550	26	11
Guideline levels ASHRAE/AIHA/EPA			65 $\mu\text{g}/\text{m}^3$ 24-hour average

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: JL Searell Date: 2/28/02

CITY_21MC100_003020879