

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 9/10/02 8:00:00 AM

ATC Group #: 8828

Analysis Date: 9/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE Murray Bergtraum HS
411 Pearl Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ	(S/cc)	(S/mm ²)	(S/cc)	
01 8828 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 8828 -2	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
03 8828 -3	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 8828 -4	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 8828 -5	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 8828 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 8828 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/10/02 8:00:00 AM
 ATC Group #: 8828
 Analysis Date: 9/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE Murray Bergtraum HS
 411 Pearl Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
08 8828 -8	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
09 8828 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 8828 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 8828 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 8828 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 8828 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
14 8828 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
15 8828 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
16 8828 -16	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/10/02 8:00:00 AM
 ATC Group #: 8828
 Analysis Date: 9/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE Murray Bergtraum HS
 411 Pearl Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
17 8828 -17	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
18 8828 -18	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
19 8828 -19	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
20 8828 -20	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
21 8828 -21	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
22 8828 -22	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
23 8828 -23	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879