



104 East 25th St., 10th
New York, New York 10010
www.atc-enviro.com
212.353.8100
Fax 212.353.8101

September 19, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Department of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

**Re: Wipe Samples for Polychlorinated Biphenyls
Murray Bergtraum High School (M520)
ATC Project No. 15-19125-0351**

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of the results of wipe samples for polychlorinated biphenyls (PCBs) collected on September 11, 2002, at the referenced location. The New York City Department of Education (DOE) requested this requested this sampling to evaluate possible contamination inside the school.

Scope of Work

The samples for PCBs were collected using sterile gauze pads and hexane as a solvent. The solvent was provided and samples were analyzed by PSC Analytical Services, Inc. (PSC), an American Industrial Hygiene Association-accredited laboratory in Reading, PA. The PCB analysis was performed using EPA Method 8082B.

Sonny Ramlal, Environmental Technician of ATC's New York City office, collected the samples consistent with generally accepted industrial hygiene practices. The results of the sampling represent conditions on the date the samples were collected.

Results

ATC submitted three (3) samples and one blank for PCBs to PSC Analytical Services for analysis. A copy of the analytical laboratory report is provided in the Attachment.

The areas sampled were: the Lobby-Main Entrance, 3rd floor Hallway by Room 339 and 5th Floor Hallway by Room 518. The surface area was 100 square centimeters (100cm²).

The samples were analyzed for seven PCB compounds with differing percentages of chlorine.

Mr. Bernard P. Orlan
Wipe Samples for PCBs
Murray Bergtraum H.S. (M520)


September 19, 2002
Page 2
ATC Project No. 15-19125-0351

The PCB result for all the samples were *below the reporting limits* (2.0 micrograms/sample) for the analysis.

Currently, the Environmental Protection Agency spill clean-up standard for PCBs on non-porous surfaces is 10 micrograms per 100 square centimeters or less (<10ug/100cm²) as stated in 40 CFR 751.


It is our pleasure to provide these indoor environmental services to the New York City Department of Education. If you have any questions about this report, please call (212) 353-8280, extension 070 or 212.

Sincerely,
ATC ASSOCIATES INC.



Tenzin Namgyal
Industrial Hygienist

Reviewed by:



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment