
**SAFETY ENVIRONMENTAL
CO. OF N.Y. INC.**

(718) 390-0914
Fax (718) 390-0915

33 Clinton Avenue
Staten Island, NY 10301

CLIENT: NYC D.O.T.

SITE: 2 RECTOR STREET, NEW YORK, NY

RE: ASBESTOS AIR MONITORING AND TESTING 6TH FLOOR OFFICE SPACES

DATE SAMPLE COLLECTED: 9/25/01

DATE SAMPLE ANALYZED: 9/26/01

FILE NO.: 01-137

BATCH #: 9-017

SAMPLE TYPE: AIR QUALITY

CERTIFICATE OF ANALYSIS


Airborne asbestos analysis by NIOSH method no. 7400-phase contrast microscopy New York State ELAP # 11475, American Industrial Hygiene association # 17049. Microscope Type-PCM, Make-Olympus, Model CH-2

SAMPLE NUMBER	SAMPLE LOCATION	TOTAL TIME SAMPLED (MIN)	FLOW RATE (L/Min)	VOLUME (L)	RESULTS FIBERS/ CC
AQ1	CENTER OF GHIN OFFICE	120	10	1200	0.002
AQ2	CENTER DEP DIRECTOR OFF	120	10	1200	0.003
AQ3	CENTER FABRE-J OFFICE	120	10	1200	0.002
AQ4	FRIDMAN CUBICLE	120	10	1200	0.002
AQ5	MAKARIOUS OFFICE	120	10	1200	0.002
AQ6	CORRIDOR NR EX D ENTRANCE	120	10	1200	0.003
AQ7	RM 6NW BLUE PRINTS FILE	120	10	1200	0.003
AQ8	SHAH & BERENS OFFICE	120	10	1200	0.005
AQ9	ELEVATOR BANK	120	10	1200	0.004
AQ10	KESTELBOYM OFFICE	120	10	1200	0.004
AQ11	CORRIDOR SW END	120	10	1200	0.004
AQ12	CORRIDOR CENTER OF S SIDE	120	10	1200	0.003
AQ13	CENTER OF RM 3 WEST	120	10	1200	0.003
AQ14	COPIER ROOM	120	10	1200	0.004


Environmental Engineering Consultant • Asbestos, Lead, and Gas Air Monitoring & Testing, Inspections
Project Management • Laboratory Analytical Testing Services • Abatement Design • Phase 1 & 2

CITY_21MC100_006678148

SAMPLE NUMBER	SAMPLE LOCATION	TOTAL TIME SAMPLED (MIN)	FLOW RATE (L/Min)	VOLUME (L)	RESULTS FIBERS/ CC
AQ15	JAIN OFFICE	120	10	1200	0.004
AQ16	HUNG OFFICE	120	10	1200	0.003
AQ17	RAHMAN OFFICE	120	10	1200	0.002
AQ18	CORRIDOR ON EX E SIDE	120	10	1200	0.003
AQ19	CENTER EXEC ASSIS OFFICE	120	10	1200	0.003
AQ20	CHAN OFFICE	120	10	1200	0.002
AQ21	DEMADET OFFICE	120	10	1200	0.002
AQ22	BLANK	120	10	1200	ND
AQ23	BLANK	120	10	1200	ND



Jane Kozlovskaya
Laboratory Analyst



Francis Owoh M.S., RPIH
Laboratory Director