NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	Cole	**Volume (liters):**	450
Lab Group #:	7839	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	2	**Grid Opening Size:**	0.01124
Client Sample #:	2	**Area Examined:**	0.1124 mm²
GRID BOX:	1162	**Magnification:**	20,000
GRID ID:	7AC	**Accelerating Voltage:**	100 KeV
# Grid Openings:	10	**Analysis Date:**	5/23/02

Analysis Performed By: MARK PEYSAKHOV

GO. No Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb 23/6;5:	Ambig/ND	EDS (Nonadb Elements)
1 EE	NSD									NSD		
2 JC	— "									— "		
3 QZ	— "									— "		
4 XZ	— "									— "		
5 VZ	— "									— "		
6 BB	— "									— "		
7 EB	— "									— "		
8 JB	— "									— "		
9 QQ	— "									— "		
10 XB	— "									— "		

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES

Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000208588