

FROM : TSC

TOTAL P.03

CITY_21MC100_007210775

TOTAL SAFETY CONSULTING, LLC
6 HIGHLAND AVENUE
STATEN ISLAND, NY 10301
(718) 273-5113 (0)

DUST WIPE
CHAIN OF CUSTODY TRANSMITTAL
BULK SAMPLES

PAGE 1 OF 1

01113793

CLIENT Turner Construction PROJECT# 201113793
PROJECT 30 W. Broadway, N.Y. N.Y. (Fiterman Hall) PROJECT#
LABORATORY: Sci-Lab, NY, NY
ANALYSIS ☒ PLM ☐ TEM ☐ OTHER
TURNAROUND 48HRS ☒ 24HRS ☐ OTHER:
FOR RUSH TURNAROUND, CONTACT: Fax results to 718-815-6162 & 419-858-4038 E-fax
SAMPLES COLLECTED BY: Fred Milteer DATE/TIME 11/28/01
TRANSMITTED TO LAB BY: Fed Ex DATE/TIME 11/29/01
RECEIVED IN LAB BY: CJ Flemming DATE/TIME 11/30/01 0930
SAMPLES ANALYZED BY: DATE/TIME

COMMENTS: STOP AT 1ST (N) FOR EACH GROUPING FOR PLM/TEN ELAP ANALYSIS

[illegible]

Results

NDU-30-2001 16:49

SCIENTIFIC LABS


212 679 9392 P.03/03

SciLab Job#: 201113793

Client Name: Total Safety Consulting, LLC

Table I
Summary of Bulk Asbestos Analysis Results
 Turner Construction; 30 W. Broadway, (Fiterman Hall), NY

SciLab Sample #	Client Sample# Location	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	Asbestos by PLM/DS	Asbestos by TEM
01	Blank		---	---	---	---	NVA	NA
02	Blank							
	13C		---	---	---	---	NVA	NA
	13t Floor South "C"							
03	9C		---	---	---	---	NVA	NA
	9th Floor South "C"							
04	4C		---	---	---	---	NVA	NA
	4th Floor South "C"							
05	1C		---	---	---	---	NVA	NA
	1st Floor South "C"							

 Analyzed by: John Koubiadis  Date Analyzed: 11/30/01

*NAD/NSD = no asbestos detected; NA = not analyzed; NAPS = not analyzed / positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab #200546-0) and ELAP PLM Analytical Protocol 198.1 for New York samples (NYSDOH ELAP Lab # 11480); ELAP TEM Analysis Protocol 198.4 for negative NY NOB samples. Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (also see EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the laboratory. This PLM report relates ONLY to the items tested.
 AIHA# 102843; VT Cert# AL016055 NVA=No Visible Asbestos

Reviewed By: _____

NOV-30-2001 16:49

SCIENTIFIC LABS

212-679-9392 P.02/03

CITY_21MC100_007210776