

PAGE 02/02

KAM CONSULTANTS

7187293774

03/21/2002 12:50

CITY_21NC100_010394985



KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTODY FOR ASBESTOS AIR MONITORING

CLIENT: NYC-DDC
PROJECT: Stuyvesant H.S.

SAMPLING DATE: 3-20-02
ADDRESS: 345 Chambers St., NY, NY 10282

TO 20321 A

FIELD DATA							LAB ANALYSIS			
SAMPLE #	LOCATION	TIME IN	TIME OUT	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	STRUCTURES DETECTED		Structure Density (struc/m ³)	Structure Concentration (struc/cc)
							0.5-5.0 (µ)	>5.0 (µ)		
D1	North School Entrance - West	07:44	17:35	3	3	1773	0	0	420.0	60.0044
D2	" - East	07:48	17:37	3	3	1767	0	0	420.0	60.0044

KAM CONSULTANTS
102 MAR 21 11:22

TECHNICIAN: L. PROCHNIEWICZ		ROTAMETER: KAM101
CHAIN OF CUSTODY	PLEASE FAX RESULTS TO DDC -EHSS	RECEIVED AT LAB BY: <i>UN</i>
		SAMPLE CONDITION UPON RECEIPT: <i>GOOD</i>
		DATE/TIME:

ANALYST: *ALLEN BARRON/6045* DATE RECEIVED: *3-20-02* DATE OF ANALYSIS: *3-21-02*

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) EPA 40 CFR Part 763 (ASHERA)
Sample Volume may be below recommended limit of the method.
FAX RESULTS TO (212) 941-5356