NYC 9/11 Public Portal Document

KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTODY FOR ASBESTOS AIR MONITORING

CLIENT: NYC-DDC
PROJECT: Stuyvesant H.S.
SAMPLING DATE: 11/26/01
ADDRESS: 345 Chambers St., NY, NY 10282

T011127A

FIELD DATA							LAB ANALYSIS			
SAMPLE #	LOCATION	TIME IN	TIME OUT	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	STRUCTURES DETECTED 0.5-5.0 (μ)	STRUCTURES DETECTED >5.0 (μ)	Structure Density (struc/mm²)	Structure Concentration (struc/cc)
	Piez #25									
1	North ex. of Stuyvesant H.S.	1600	2400	3	3	1440	0	0	<16.67	<0.0045
2	↓ North west	1601	2401	3	3	1440	0	0	<16.67	<0.0045

TECHNICIAN: D. SALIS
ROTAMETER: KAM101

CHAIN OF CUSTODY		
	FAX results to N.Y.C DDC.	RECEIVED AT LAB BY: SAMPLE CONDITION UPON RECEIPT: DATE/TIME:

RECEIVED
KAM CONSULTANTS
2001 NOV 27 AM 7 55

ANALYST: [signature] DATE RECEIVED: 11/27 DATE OF ANALYSIS 11/27

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) EPA 40 CFR Part 763 (AHERA)
Sample Volume may be below recommended limit of the method.
FAX RSULTS TO (212) 941-5356

11/27/2001 12:41 7187293774 KAM CONSULTANTS PAGE 02/03
CITY_21MC100_010395353
NYC-WTC_000208843