

ANALYSIS REPORT ASBESTOS IN AIR Transmission Electron Microscopy

CLIENT: NYC-DPC
 PROJECT: STUYVESANT H.S.

Lab ID#	Client Sample ID#	Sample Location	Volume (liters)	Grid Openings Examined	Filter Area (mm ²)	Analytical Sensitivity (struct/cc air)	Asbestos Type(s)	Asbestos Structures Detected (microns)			Structure Density (struct/mm ²) Total	Structure Concentration (struct/cc) Total
								0.5-5.0	>5.0	Total		
T01101015 ⁰¹	1	PIER-25-NORTH	1296.4	6	385	0.0049	0	0	0	0	<16.6	<0.0049
T-02	2	PIER-15-EAST SIDE	1586	6	↓	0.0046	0	↓	↓	↓	↓	<0.0046
T-03												
T-04												
T-05												
T-06												
T-07												
T-08												
T-09												
T-10												

Area Analyzed: 0.06 mm²
 Grid Opening Area: 0.009573 mm²
 Date Collected: 0.010

Date Received: 10/10/01
 Date Analyzed: 10/10/01
 Date of Report:

Analyst: David Chen

Lab Director: George Kouvaras

Analysis performed according to AHERA Method (EPA 40 CFR Part 763 - Appendix A) Samples will be stored for ninety (90) days and then returned to the client upon request.

AIHA #: 100269

NIST-NVLAP #: 102047

NYS-DOH ELAP#: 11273

CITY_21NC100_010395380