

JUN-10-2002 MON 06:40 PM

FAX NO.

P. 23



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 609-0009 - Fax: (516) 609-8271

Laboratory Report

AGL01955

Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP ID#101618-0; NY ELAP ID#10865

Client:	Cushman & Wakefield a/a/f Deutsche Bank	Job Number:	211909
Address:	130 Liberty Street	Date Received:	02/13/2002
	New York NY 10005	Date Analyzed:	2/16/02
Collected By:	Customer	Job Location:	130 Liberty Street
Collected:	02/09/2002		

Lab ID Field ID	Sample Location	Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0001955-001 14-A-01	14th Floor: NE Corner	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 2%	Cellulose Fiber 20% Mineral Wool 40% Non-Fibrous Material 38%
0001955-002 14-A-02	14th Floor: Middle of North Wall	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 2%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 28%
0001955-003 14-A-03	14th Floor: NW Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 3%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 27%
0001955-004 12-A-01	12th Floor: NE Corner	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 40% Mineral Wool 30% Non-Fibrous Material 29.5%
0001955-005 12-A-02	12th Floor: Middle of North Wall	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 40% Mineral Wool 30% Non-Fibrous Material 29.5%
0001955-006 12-A-03	12th Floor: NW Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 29.5%
0001955-007 11-A-01	11th Floor: NE Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.3%	Cellulose Fiber 20% Mineral Wool 30% Non-Fibrous Material 49.2%
0001955-008 11-A-02	11th Floor: Middle of North Wall	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 20% Mineral Wool 30% Non-Fibrous Material 49.5%

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10865

Client: Cushman Wakefield a/a/ Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-01	Level B/Metal Shelf (No Ceiling)	Chrysotile (3,257)					
211909	4/22/02	211909-10	Level B/Top Of Vending Machine	Chrysotile (608,682)					
211909	4/22/02	211909-10P	Level B/Top Of Light Fixture	Chrysotile & Amosite (57,001)					
211909	4/22/02	211909-02	Level B/Metal Shelf (No Ceiling)	Chrysotile & Amosite (97,716)					
211909	4/22/02	211909-03	Level B/Folder (12 Ft Ceiling - 1/2 Missing)	Chrysotile (42,751)					
211909	4/22/02	211909-09	Level B/Elevator Pit Room #23 (No Ceiling)	Chrysotile (59,037)					
211909	4/22/02	211909-11	Level B/Tabletop (12 Ft Ceiling - 1/2 Missing)	Chrysotile (150,646)					
211909	4/22/02	211909-04	Level B/Box On Shelf (12 Ft Ceiling - 1/4 Missing)	Chrysotile (46,822)					
211909	4/22/02	211909-05	Level B/Top Of Copy Machine	Chrysotile (209,683)					
211909	4/22/02	211909-05P	Level B/Top Of Light Fixture	Chrysotile & Amosite (8,143)					
211909	4/22/02	211909-06	Level B/Tabletop (No Ceiling)	ND					
211909	4/22/02	211909-07	Level B/Side Of Cabinet (No Ceiling)	Chrysotile (57,001)					
211909	4/22/02	211909-08	Level B/Top Of Desk (No Ceiling)	Chrysotile (81,430)					

211909 A,B, and 1st Floor Asb Wipe summary Level B

06/11/2002 13:07 FAX 2129444619

AMBIENT GROUP

011

CITY 21MC100_011249576

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10865

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-14P	Level A/Ceiling Light Fixture	Chrysotile (1,357)					
211909	4/22/02	211909-20	Level A/Top Of Desk (Ceiling 3/4 Missing)	Chrysotile (105,860)					
211909	4/22/02	211909-13	Level A/Top Of Desk	Chrysotile (38,679)					
211909	4/22/02	211909-13P	Level A/Ceiling Light Fixture	Chrysotile (1,018)					
211909	4/22/02	211909-12	Level A/Top Of Desk	Chrysotile (657,550)					
211909	4/22/02	211909-12P	Level A/Ceiling Light Fixture	Chrysotile (44,787)					
211909	4/22/02	211909-17	Level A/Floor Tile	Chrysotile (21,986)					
211909	4/22/02	211909-17P	Level A/Ceiling Light Fixture	Chrysotile (48,858)					
211909	4/22/02	211909-19	Level A/Floor Tile	Chrysotile (38,644)					
211909	4/22/02	211909-19P	Level A/Ceiling Light Fixture	Chrysotile (40,715)					
211909	4/22/02	211909-18	Level A/Top Of Orange Machine (No Ceiling)	Chrysotile (27,686)					
211909	4/22/02	211909-21	Level A/Top Of Automatic Door Frame	Chrysotile (81,430)					
211909	4/22/02	211909-21P	Level A/Ceiling Light Fixture	Chrysotile (225,989)					
211909	4/22/02	211909-15	Level A/Top Of Desk	Chrysotile (50,487)					
211909	4/22/02	211909-15P	Level A/Ceiling Light Fixture	Chrysotile (20,358)					

211909 A,B, and 1st Floor Asb Wipe summary Level A

06/11/2002 13:07 FAX 2129444616

AMBIENT GROUP

012

CITY_21MC100_011249577

Ambient Group, Inc.
 10 Morris Avenue
 Glen Cove, NY 11542
 ELAP # 10865

Client: Cushman Wakefield a/a/f Deutsche Bank
 Address: 130 Liberty Street
 Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-16	Level A/Metal Shelf	Chrysotile (44,787)					
211909	4/22/02	211909-16P	Level A/Ceiling Light Fixture	Chrysotile (3,054)					
211909	4/22/02	211909-14	Level A/Top Of Metal Shelf	Chrysotile (158,337)					

211909 A,B, and 1st Floor Asb Wipe summary Level A

06/11/2002 13:08 FAX 2129444618

AMBIENT GROUP

013

CITY_21MC100_011249578

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10865

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/23/02	211909-23	1st Floor/Top Of Table	Chrysotile (213,689)					
211909	4/23/02	211909-23P	1st Floor/Ceiling Light Fixture	Chrysotile (79,144)					
211909	4/23/02	211909-24	1st Floor/Top Of Wood Shelf (Low Ceiling)	Chrysotile (348,234)					
211909	4/23/02	211909-25	1st Floor/Top Of Wood Desk	Chrysotile (158,288)					
211909	4/23/02	211909-25P	1st Floor/Ceiling Light Fixture	Chrysotile (522,350)					
211909	4/23/02	211909-26	1st Floor/Top Of Heater	Chrysotile (316,576)					
211909	4/23/02	211909-26P	1st Floor/Ceiling Light Fixture	Chrysotile (229,518)					
211909	4/23/02	211909-27	1st Floor/Floor In Corner (20 Ft Tile Ceiling)	Chrysotile (205,774)					
211909	4/23/02	211909-29	1st Floor/Floor In Corner	Chrysotile (102,887)					
211909	4/23/02	211909-30	1st Floor/In Between Two Escalators	Chrysotile (253,261)					
211909	4/23/02	211909-35	1st Floor/Top Of Metal Shelf	Chrysotile (41,154.9)					
211909	4/22/02	211909-33	1st Floor/Top Of Computer Table	Chrysotile (159,845)					
211909	4/22/02	211909-33P	1st Floor/Ceiling Light Fixture	Chrysotile (3,054)					
211909	4/22/02	211909-31	1st Floor/Top Of Desk	Chrysotile (61,073)					
211909	4/22/02	211909-31P	1st Floor/Top Of Ceiling Light Fixture	Chrysotile (122,146)					

211909 A,B, and 1st Floor Asb Wipe summary 1st Floor

06/11/2002 13:08 FAX 2129444618

AMBIENT GROUP

014

CITY_21MC100_011249579

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10865

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-32	1st Floor/Top Of Desk	Chrysotile (81,430)					
211909	4/22/02	211909-32P	1st Floor/Ceiling Light Fixture	Chrysotile (49,673)					
211909	4/22/02	211909-34	1st Floor/Top Of Computer Desk	Chrysotile (663,658)					
211909	4/22/02	211909-34P	1st Floor/Ceiling (On Duct Work)	Chrysotile (40,715)					

211909 A,B, and 1st Floor Asb Wipe summary 1st Floor

06/11/2002 13:08 FAX 2129444618

AMBIENT GROUP

015

CITY_21MC100_011249580