

ATC ASSOCIATES, INC.


Page 1 of 3

INDOOR AIR QUALITY FIELD REPORT

TIME 1500LOCATION PS89 M DATE 1-31-02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
PLAYGROUND NORTH		47.1	44.3	501	0	35	0
OUTSIDE NORTH EXIT		47.4	45.7	498	0	38	0
OUTSIDE NE CORNER		47.0	44.1	506	0	39	0
OUTSIDE NW CORNER		47.5	44.4	499	0	37	0
PLAYGROUND SOUTH		45.2	48.6	502	0	42	0
OUTSIDE SOUTH EXIT		43.8	50.9	495	0	36	0
OUTSIDE SE CORNER		44.1	49.2	497	0	39	0
OUTSIDE SW CORNER		42.8	52.6	507	0	37	0
Inside North Exit		64.9	44.6	680	0	22	0
Inside South Exit		64.8	42.3	599	0	24	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 1/31/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3

TIME _____

LOCATION P589 MDATE 1/31/02PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
502	1	68.8	41.8	670	0	22	0
508	29	69.5	42.9	999	0	20	0
512	10	70.1	40.7	952	0	17	0
526	—	70.3	38.1	760	0	18	0
Library	5	70.2	35.7	640	0	16	0
432 (Hall)	—	70.2	34.6	680	0	25	0
426	—	68.7	34.0	670	0	16	0
410	30	70.0	36.1	890	1	19	0
404	23	71.0	35.7	908	1	29	0
401		70.8	33.5	741	1	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jing Chen Date: 1/31/02

CITY_21MC100_012157762

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3

TIME _____

LOCATION PS89 M DATE 1/31/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
301		70.3	32.6	696	1	26	0
Gym		69.6	32.8	700	1	23	0
310		69.7	32.7	678	1	18	0
326		68.5	32.2	659	1	25	0
332 (Hall)		68.3	32.4	645	1	25	0
232		68.9	31.0	588	0	16	0
228		68.8	31.0	575	1	23	0
217 (Assembly)		68.9	31.4	566	1	21	0
204		69.2	31.3	580	0	25	0
202		69.7	30.7	549	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jing Choy Date: 1/31/02

CITY_21MC100_012157763