


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3TIME 13:30LOCATION M89DATE 1/24/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
South Playground		53.9	61.0	526	1	54	0
North Playground		52.7	66.4	530	1	59	0
North Exit		69.7	66.7	650	0	35	0
South Exit		69.1	52.4	622	1	28	0
Outside South		52.9	62.7	534	1	60	0
Outside North		52.3	67.1	524	0	58	0
Hall by 126		67.9	62.9	635	0	38	0
Hall by 132		66.3	57.0	640	1	27	0
Dance Room		67.6	54.2	648	0	29	0
Cafeteria		68.2	52.0	648	1	36	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 1/24/02

CITY_21MC100_012157883

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3


TIME 13:45

LOCATION M 89 DATE 1/24/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501	1	71.8	48.8	690	1	21	0
508	21	71.3	48.2	802	1	31	0
526	35	71.8	49.9	921	1	35	0
528	—	70.8	47.4	850	1	36	0
517	28	72.5	45.5	799	1	27	0
430	—	70.1	42.9	688	1	30	0
426	26	69.9	44.8	1064	1	24	0
410	37	70.1	43.4	948	1	29	0
406	6	70.2	43.4	890	1	31	0
404	11	70.6	44.5	961	1	30	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 1/24/02

CITY_21MC100_012157884

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3TIME 14:05LOCATION M89 DATE 1/24/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
302	—	69.1	42.2	708	1	25	0
306	—	69.3	42.4	726	1	29	0
Gym	28	70.2	44.9	801	1	32	0
Hall by 316	—	69.9	45.1	819	1	35	0
332	—	68.2	43.2	690	1	30	0
230	—	68.9	42.5	623	1	31	0
226	—	69.3	42.2	581	1	40	0
Auditorium	15	69.5	42.7	622	1	27	0
204	—	69.2	42.5	599	1	31	0
208	5	69.2	42.2	611	1	31	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jiri Ch Date: 1/24/02