

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8TIME 8:10LOCATION P589 M DATE 2/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
North Playground		37.0	25.7	505	0	48	0
South Playground		36.5	25.9	500	0	50	0
Exit North		36.0	25.6	498	0	53	0
Exit South		35.8	25.4	493	0	47	0
NE Corner		36.3	24.2	490	0	45	0
NW Corner		35.1	24.9	485	0	48	0
SE Corner		36.5	25.5	483	0	49	0
SW Corner		35.3	25.7	480	0	50	0
Inside Exit North		69.3	32.0	526	0	34	0
Inside Exit South		69.5	31.5	535	0	33	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jim Chen Date: 2/6/02

CITY_21MC100_009253212

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8TIME 8:30LOCATION PS89 M DATE 2/6/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Cafeteria	—	73.9	12.9	535	0	21	0
Hall by Elevator		72.9	12.2	502	0	29	0
501	17	72.9	13.7	611	0	11	0
502	1	74.4	13.2	519	0	20	0
504 (Hall)		73.8	12.9	538	0	20	0
506	20	73.9	14.4	799	0	26	0
508	34	72.8	13.7	890	0	21	0
520 (Hall)	—	72.3	13.6	635	0	23	0
517	3	71.6	13.1	661	0	20	0
Stair 1 (Hall)	—	71.6	13.1	643	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: J. Ch Date: 2/6/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8

TIME 9:00

LOCATION PS89M


DATE 2/6/02

PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
432 (Hall)		70.4	13.3	550	0	22	0
426	—	70.3	13.0	488	0	28	0
410 (Hall)	10	70.9	13.8	584	0	22	0
408	19	71.4	14.1	802	0	24	0
404	29	71.9	16.3	799	0	25	0
402	30	70.8	16.4	1004	0	30	0
401 (Hall)	—	70.9	15.2	749	0	22	0
301	3	71.3	13.8	563	0	17	0
302	—	68.5	13.0	511	0	31	0
304 (Hall)	—	69.3	13.8	565	0	29	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/6/02

CITY_21MC100_009253214

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 9:50LOCATION PS89 MDATE 2/6/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Gym		70.2	15.3	538	0	18	0
310 (Hall)		70.1	14.7	534	0	26	0
330		69.5	16.6	488	0	24	0
328		70.2	13.8	478	0	28	0
Stair # 1		68.4	13.3	480	0	32	0
219 (Hall)		68.9	13.4	498	0	22	0
Auditorium		74.0	14.2	516	0	17	0
204 (Hall)		71.4	13.8	512	0	20	0
201		70.6	15.0	519	0	18	0
202 (Hall)		70.7	14.3	514	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jin Chy. Date: 2/6/02

CITY_21MC100_009253215