

Page of

DATE: 6/7/02 PROJECT NO:

Comments:

Signature: James J. [illegible]

Date: 6/07/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of

Time: 1:05 pm

LOCATION: PS 150

DATE: 6/07/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
MAIN REJER	0	73.8	45.7	686	1	12	0
MAIN DESK	1	73.8	45.5	717	1	13	0
NEXT TO WEST STAIRS HALL	0	73.6	45.6	699	1	10	0
MAIN LOBBY	3	73.9	44.9	790	1	9	0
EDS ROOM	1	73.9	45.6	731	1	10	0
MAIN OFFICE	3	72.9	42.4	645	1	10	0
GUIDANCE ROOM	1	72.8	44.6	710	1	6	0
NEXT TO BOYS RM HALL	0	74.4	45.0	646	1	6	0
NEXT TO GIRLS RM HALL	0	74.4	44.8	610	1	8	0
NEXT TO EAST STAIRS HALL	0	74.3	44.7	581	1	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/07/02

CITY_21MC100_009253274

06/10/2002 10:27 FAX 212 353 8308
ATC
008

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page of Time: 2:10 pm LOCATION: PS 150DATE: 6/7/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
Hallway NEXT TO STAFF Rm	0	74.3	45.2	609	1	17	0
402	25	74.9	45.0	1241	1	17	0
401	26	74.0	43.5	1131	1	12	0
Hall BY WEST STAIRS	0	73.7	52.7	710	1	11	0
501	0	72.4	48.7	581	1	13	0
502	0	72.6	48.1	809	1	16	0
503	26	73.5	51.0	1062	1	16	0
504	24	75.5	53.5	1262	1	10	0
504 HALLWAY	0	73.9	51.7	641	1	9	0
Hall BY EAST STAIRS	0	73.9	52.5	686	1	13	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/7/02

06/10/2002 10:27 FAX 212 353 8308

ATC

009

CITY_21MC100_009253275

NYC-WTC_000209151