

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

TIME 810

LOCATION PS89 M


DATE 3/25/02

PROJECT NO. 19125-297

Location Outside	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Playground N		50.3	20.7	370	0	16	0
Playground S		50.0	21.0	373	0	19	0
SE Corner		49.8	21.3	378	0	18	0
East Side		49.5	21.6	385	0	19	0
NE Corner		49.1	21.8	389	0	17	0
North Exit		48.8	22.0	390	0	14	0
NW Corner		48.5	21.8	387	0	17	0
By Air Intake		48.3	21.5	391	0	14	0
SW Corner		48.0	21.7	386	0	18	0
South Exit		47.9	22.0	381	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8

TIME 830

LOCATION PS89 M


DATE 3/23/02

PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair 1		67.8	22.5	458	0	10	0
132		67.9	22.9	503	0	9	0
132B	5	68.0	23.4	525	0	10	0
132C		68.3	23.3	530	0	8	0
132D		68.2	23.4	528	0	8	0
North Exit		68.0	21.0	501	0	10	0
Dance Rm.		68.5	20.8	455	0	8	0
Hall by Cafeteria		69.1	20.4	453	0	11	0
Cafeteria		68.9	20.1	456	0	11	0
Exit South Exit		69.5	19.8	460	0	13	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/23/02

03/26/2002 08:46 FAX 212 353 8306

ATC

008

CITY_21MC100_009253429

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8


TIME 900

LOCATION P589 M DATE 3/25/02 PROJECT NO. 19125-297

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
501	24	70.2	21.2	636	0	7	0
502 (Hall)	-	70.4	21.1	645	0	67	0
Hall by Stair 3	-	70.1	20.4	629	0	8	0
504	32	70.8	23.9	1290	0	19	0
506	23	70.8	23.5	1030	0	15	0
515	5	70.7	21.4	783	0	12	0
508	28	70.9	26.6	1512	0	11	0
510	1	71.9	26.6	1104	0	11	0
512 (Hall)	-	71.3	21.3	685	0	9	0
Hall by Stair 2	-	71.2	21.0	669	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 3/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8TIME 930LOCATION P589 MDATE 3/25/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
526		70.8	20.6	699	0	9	0
528 (Hall)		70.5	19.2	534	0	11	0
517	6	70.6	18.5	493	0	9	0
532	1	70.3	19.5	599	0	9	0
519	14	70.4	20.2	713	0	10	0
432	20	69.3	21.9	773	0	11	0
419	3	69.6	20.7	687	0	10	0
430	14	69.8	21.2	615	0	9	0
428 (Hall)		69.9	19.2	513	0	10	0
426	30	70.4	26.1	1382	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS89 MDATE 3/25/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Stair 2		70.4	21.0	670	0	10	0
410	3	71.1	21.0	531	0	6	0
408 (Hall)		70.9	20.2	537	0	10	0
Hall by Elevator		70.7	19.2	539	0	11	0
404	38	70.8	19.9	969	0	10	0
401	8	70.5	19.4	593	0	8	0
402	30	70.7	26.7	1380	0	10	0
Hall by Stair 3		69.9	19.4	560	0	9	0
301	1	69.8	19.3	546	0	6	0
301 (Hall)		69.8	19.3	542	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

3/25/02

03/26/2002 08:48 FAX 212 353 8308

ATC

011

CITY_21MC100_009253432

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8TIME 1100LOCATION PS89M DATE 3/25/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
326		70.7	18.6	530	0	10	0
328	10	70.5	20.5	726	0	8	0
330	12	70.6	19.8	701	0	11	0
332	17	70.8	20.1	729	0	8	0
319	—	71.3	19.9	618	0	8	0
319 (Hall)		71.0	20.1	643	0	11	0
Hall by Stair 1		68.5	19.6	550	0	9	0
219	2	69.9	19.5	548	0	10	0
232	3	70.4	20.2	562	0	7	0
230		70.4	19.7	492	0	8	0
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

3/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 6 of 8TIME 1030LOCATION P589 MDATE 3/25/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
302	15	70.9	21.4	742	0	7	0
304	11	72.3	22.1	738	0	10	0
306	16	71.6	21.6	902	0	13	0
315 (Hall)		71.4	21.4	700	0	12	0
315	Full	70.2	19.2	561	0	12	0
308		71.0	19.2	528	0	11	0
310		71.1	19.2	538	0	12	0
314 (Hall)		70.6	18.8	518	0	11	0
316 (Hall)		70.6	18.6	501	0	11	0
Hall by Stair 2		70.5	18.7	503	0	10	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 3/25/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 8 of 8TIME 1130LOCATION PS89MDATE 3/25/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
228	14	70.1	22.1	783	0	11	0
226	16	70.2	20.8	673	0	11	0
Hall by Stair 2		70.2	19.8	602	0	9	0
208 (Hall)		70.1	19.6	582	0	9	0
Auditorium		69.6	18.2	483	0	8	0
204	18	70.0	25.0	983	0	16	0
Hall by Elevator		69.9	21.9	620	0	9	0
202 (Hall)		69.7	19.4	600	0	9	0
201		69.4	19.5	562	0	6	0
201 (Hall)		69.5	19.6	590	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____



Date: _____

3/25/02