NYC 9/11 Public Portal Document

TESTWELL LABORATORIES, INC.
Environmental Laboratory
47 Hudson Street, Ossining, New York 10562

NYS ELAP # 11142
NVLAP # 200083-0
AIHA # 100147

Transmission Electron Microscopy Results

Client: **Bovis Lend Lease - LMB**
200 Park Avenue
New York, New York

Sample Location: Millenium Hilton Hotel @ WTC Various Floors
55 Church Street
New York, New York

Field Technician: B. Gitman

Filter Type: MCE 0.45 micron
Avg.Grid Opening: 0.0121mm²

Date Collected: 07/19/02
Date Rec'd (lab): 07/22/02
Analysis Date: 07/24/02
TEM Analyst: *D. McCarl*
Analytical Method: **AHERA**

Sample #:	Sample Location:	Lab Number 02TEM #	Volume Coll. (liters)	Grid Openings Analyzed	Grid Area Analyzed	Countable Asb. Structures	Concentration Structures/mm²	Concentration Structures/cc
299	Lobby	4824	1280.0	6	0.073	1	**13.77**	**0.004**
300	Lobby	4825	1280.0	6	0.073	0	**<13.77**	**<0.004**
301	Lobby	4826	1280.0	6	0.073	0	**<13.77**	**<0.004**
302	Lobby	4827	1280.0	6	0.073	0	**<13.77**	**<0.004**
303	Lobby	4828	1280.0	6	0.073	0	**<13.77**	**<0.004**
304	Field Blank	4829	0.0	6	0.073	0	**<13.77**	**<0.004**
305	Field Blank	4830	0.0	6	0.073	0	**<13.77**	**<0.004**
							Structures/mm²	Structures/cc
				Total Average Concentrations			**<13.77**	**<0.004**

This report is the confidential property of our clients. This certificate of analysis/report shall not be used by the client to claim product endorsement by the National Voluntary Laboratory Approval Program (NVLAP) or any agency of the United States Government. The laboratory has no control over air sampling collection. This certificate of analysis/report shall not be reproduced in full, without the written approval of Testwell Laboratories, Inc.

Laboratory Director/Approved Signatory